

Upcoming High-Impact Outages (HIOs) in the NEM - Information Current as of: 20 September 2021 - 1155 hrs -

Legend

Newly Added Outage Update(s) since the last notification

Withdrawn since the last notifcation

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNSP Aware?	Generator Aware?	Reason and Duration
NSW	Transgrid	20/09/2021 06:29 Monday	20/09/2021 18:00 Monday	Tamworth No.3 330 kV Bus	< <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM</new>	Day: 2 hrs Night: NA	Planned - RESUBMIT		~	~	Commissioning 11.5 Hours
vic	AusNet	20/09/2021 06:52 Monday	20/09/2021 19:00 Monday	Jindera - Wodonga (060) 330 kV Line	< <updated last="" notification="" since="" the="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.</updated>	Day: 2 hrs Night: NA	In Progress - PTP		~	~	Maintenance 12.1 Hours
NSW	Transgrid	20/09/2021 06:53 Monday	20/09/2021 19:00 Monday	Jindera - Wodonga (060) 330 kV Line	< <updated last="" notification="" since="" the="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 KV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.</updated>	Day: 2 hrs Night: NA	In Progress - PTP		~	~	Maintenance 12.1 Hours
NSW	Transgrid	21/09/2021 06:00 Tuesday	21/09/2021 18:00 Tuesday	Tamworth No.3 330 kV Bus	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 2 hrs Night: NA	Planned - STLTP		~	~	Commissioning 12 Hours

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNSP Aware?	Inter-Regional	Reason and Duration
VIC	AusNet	21/09/2021 07:00 Tuesday	21/09/2021 19:00 Tuesday	Heywood - Mortlake 500 kV Line	< <this been="" has="" outage="" withdrawn!="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</this>	Day: 2 hrs Night: NA	Withdrawn				Maintenance 12 Hours
VIC	ΤΟΑ	21/09/2021 07:00 Tuesday	21/09/2021 17:00 Tuesday	Ararat - Waubra 220 kV Line	A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2.5 hrs Night: NA	Planned - MTLTP		× ,	~ ~	Maintenance 10 Hours
VIC	AusNet	21/09/2021 17:00 Tuesday	21/09/2021 23:00 Tuesday	Heywood - South East No.1 275 kV Line	< <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new>	Day: 2 hrs Night: NA	Planned - SUBMIT			~	Maintenance 6 Hours
VIC	AusNet	22/09/2021 07:00 Wednesday	22/09/2021 19:00 Wednesday	Heywood - Mortlake 500 kV Line	< <this been="" has="" outage="" withdrawn!="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</this>	Day: 2 hrs Night: NA	Withdrawn				Maintenance 12 Hours
VIC	ΤΟΑ	22/09/2021 07:00 Wednesday	22/09/2021 17:00 Wednesday	Ararat - Waubra 220 kV Line	A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: NA	Planned - MTLTP		✓ ,	 ✓ 	Maintenance 10 Hours

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned? DNSP <u>Aware</u> ?	Generator Aware?	Inter-Regional	Reason and Duration
VIC	AusNet	22/09/2021 17:00 Wednesday	22/09/2021 23:00 Wednesday	Heywood - South East No.1 275 kV Line	< <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new>	Day: 2 hrs Night: NA	Planned - SUBMIT			~	Maintenance 6 Hours
NSW	Transgrid	23/09/2021 06:00 Thursday	27/09/2021 12:00 Monday	Dumaresq - Sapphire 330 kV line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 8 hrs Night: 8 hrs	Planned - MTLTP		~	~	Commissioning 4.3 Days
VIC	AusNet	23/09/2021 07:00 Thursday	23/09/2021 19:00 Thursday	Heywood - Mortlake 500 kV Line	< <this been="" has="" outage="" withdrawn!="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</this>	Day: 2 hrs Night: NA	Withdrawn				Maintenance 12 Hours
VIC	AusNet	28/09/2021 06:45 Tuesday	28/09/2021 17:00 Tuesday	Hazelwood - South Morang No.2 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could cause a large reduction in generation in Victoria.	Day: 1 hr Night: NA	Planned - MTLTP				Maintenance 10.3 Hours
NSW	Transgrid	28/09/2021 08:00 Tuesday	28/09/2021 17:00 Tuesday	Tamworth Liddell PS (84) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 2 hrs Night: 2 hrs	Planned - MTLTP	~	 ✓ 	~	Commissioning 9 Hours
VIC	AusNet	28/09/2021 17:00 Tuesday	28/09/2021 17:30 Tuesday	Hazelwood - South Morang No.2 500 kV Line	< <new last="" notification="" since="" the="">> This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could cause a large reduction in generation in Victoria.</new>	Day: 30 mins Night: NA	Planned - SUBMIT				Maintenance 30 Minutes

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNSP Awares Generator Aware?	Inter-Regional	Reason and Duration
VIC	AusNet	29/09/2021 07:00 Wednesday	29/09/2021 19:00 Wednesday	Heywood - Tarrone 500 kV Line	< <this been="" has="" outage="" withdrawn!="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</this>	Day: 2 hrs Night: NA	Withdrawn				Maintenance 12 Hours
NSW	Transgrid	30/09/2021 06:00 Thursday	30/09/2021 18:00 Thursday	Tamworth No.1 330 kV Bus	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 2 hrs Night: 2 hrs	Planned - MTLTP		/	~	Commissioning 12 Hours
NSW	Transgrid	30/09/2021 06:00 Thursday	30/09/2021 18:00 Thursday	Armidale - Tamworth (86) 330 kV Line	< <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM</new>	Day: 2 hrs Night: NA	Planned - MTLTP		~	~	Maintenance 12 Hours
NSW	Transgrid	30/09/2021 06:00 Thursday	30/09/2021 18:00 Thursday	Tamworth Liddell PS (84) 330 kV Line	< <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM</new>	Day: 4 hrs Night: NA	Planned - MTLTP				Commissioning 12 Hours
NSW	Transgrid	01/10/2021 06:00 Friday	01/10/2021 18:00 Friday	Tamworth No.1 330 kV Bus	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 2 hrs Night: 2 hrs	Planned - MTLTP		/	~	Commissioning 12 Hours
NSW	Transgrid	01/10/2021 06:00 Friday	01/10/2021 18:00 Friday	Armidale - Tamworth (86) 330 kV Line	< <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM</new>	Day: 2 hrs Night: NA	Planned - MTLTP		/	~	Maintenance 12 Hours
NSW	Transgrid	01/10/2021 06:00 Friday	01/10/2021 18:00 Friday	Tamworth Liddell PS (84) 330 kV Line	< <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM</new>	Day: 4 hrs Night: NA	Planned - MTLTP				Commissioning 12 Hours

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNSP Aware? Generator Aware?	Inter-Regional	Reason and Duration
VIC	AusNet	01/10/2021 06:45 Friday	01/10/2021 17:00 Friday	South Morang - Sydenham No.1 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 1 hr Night: NA	Planned - MTLTP				Maintenance 10.3 Hours
NSW	Transgrid	02/10/2021 06:00 Saturday	02/10/2021 18:00 Saturday	Armidale - Tamworth (86) 330 kV Line	< <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM</new>	Day: 2 hrs Night: NA	Planned - MTLTP		~	~	Commissioning 12 Hours
NSW	Transgrid	02/10/2021 06:00 Saturday	02/10/2021 18:00 Saturday	Tamworth No.1 330 kV Bus	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 2 hrs Night: 2 hrs	Planned - MTLTP		~	~	Commissioning 12 Hours
NSW	Transgrid	02/10/2021 06:00 Saturday	02/10/2021 18:00 Saturday	Tamworth Liddell PS (84) 330 kV Line	< <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM</new>	Day: 4 hrs Night: NA	Planned - MTLTP		~	~	Commissioning 12 Hours
NSW	Transgrid	04/10/2021 06:00 Monday	04/10/2021 17:00 Monday	Liddell to Muswellbrook (83) 330 kV Line	< <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM</new>	Day: 4 hrs Night: NA	Planned - SUBMIT				Commissioning 11 Hours
TAS	TasNetworks	04/10/2021 07:00 Monday	04/10/2021 15:00 Monday	Sheffield - Farrell No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2 hrs Night: NA	Planned - MTLTP		~		Maintenance 8 Hours
TAS	TasNetworks	05/10/2021 06:00 Tuesday	05/10/2021 16:00 Tuesday	Sheffield - Farrell No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 1.5 hrs Night: NA	Planned - MTLTP		~		Maintenance 10 Hours
VIC	AusNet	19/10/2021 06:00 Tuesday	19/10/2021 16:00 Tuesday	Keilor – Sydenham 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 3 hrs Night: NA	Planned - SUBMIT				Maintenance 10 Hours
QLD	Powerlink	25/10/2021 07:00 Monday	27/10/2021 14:00 Wednesday	Nebo - Broadsound (8847) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: NA Night: NA	Planned - SUBMIT				Commissioning 2.3 Days

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNSP Aware?	Generator Aware?	Lte-Yegonal Reason al Duration
QLD	Powerlink	27/10/2021 14:01 Wednesday	06/11/2021 17:00 Saturday	Nebo - Broadsound (8847) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: NA Night: NA	Planned - SUBMIT				Commissior 10.1 Day
NSW	Transgrid	01/11/2021 05:30 Monday	01/11/2021 16:00 Monday	Wagga - Darlington Point (63) 330 kV Line	 This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer Between Victoria and New South Wales. Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: 2 hrs Night: NA	Planned - SUBMIT		~	~	✓ Maintenan 10.5 Houi
NSW	Transgrid	01/11/2021 06:00 Monday	06/11/2021 16:00 Saturday	Lower Tumut - Wagga (051) 330 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 48 hrs Night: 48 hrs	Planned - SUBMIT		~	~	✓ Commissior 5.4 Days
VIC	AusNet	04/11/2021 06:00 Thursday	04/11/2021 18:00 Thursday	Heywood - Tarrone 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.	Day: 2 hrs Night: NA	Planned - SUBMIT				Maintenan 12 Hours

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNSP Aware? Generator Aware?	Inter-Regional	Reason and Duration
VIC	AusNet	05/11/2021 06:00 Friday	05/11/2021 18:00 Friday	Heywood - Tarrone 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.	Day: 2 hrs Night: NA	Planned - SUBMIT				Maintenance 12 Hours
NSW	Transgrid	06/11/2021 05:00 Saturday	10/11/2021 17:00 Wednesday	Armidale - Tamworth (86) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: 4 hrs	Planned - SUBMIT				Commissioning 4.5 Days
VIC	AusNet	06/11/2021 06:00 Saturday	06/11/2021 18:00 Saturday	Heywood - Tarrone 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.	Day: 2 hrs Night: NA	Planned - SUBMIT				Maintenance 12 Hours
QLD	Powerlink	08/11/2021 14:00 Monday	08/11/2021 15:00 Monday	Ross No.2 288/138/19 kV Transformer	< <this been="" has="" outage="" withdrawn!="">> This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.</this>	Day: 5 mins Night: NA	Withdrawn				Maintenance 60 Minutes
QLD	Powerlink	09/11/2021 11:00 Tuesday	09/11/2021 11:30 Tuesday	Ross No.3 288/138/19 kV Transformer	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 5 mins Night: NA	Planned - SUBMIT				Maintenance 30 Minutes
QLD	Powerlink	10/11/2021 10:00 Wednesday	10/11/2021 10:30 Wednesday	Ross No.4 288/138/19 kV Transformer	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 5 mins Night: NA	Planned - SUBMIT				Maintenance 30 Minutes
TAS	TasNetworks	16/11/2021 07:00 Tuesday	16/11/2021 15:00 Tuesday	Gordon - Chapel St No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2 hrs Night: NA	Planned - SUBMIT		~		Maintenance 8 Hours

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	Generator Aware?	Inter-Regional	Reason and Duration
TAS	TasNetworks	17/11/2021 07:00 Wednesday	17/11/2021 15:00 Wednesday	Gordon - Chapel St No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2 hrs Night: NA	Planned - SUBMIT		~		Maintenance 8 Hours
QLD	Powerlink	30/11/2021 08:30 Tuesday	30/11/2021 17:00 Tuesday	Broadsound - Nebo (834) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 3 hrs Night: NA	Planned - SUBMIT				Maintenance 8.5 Hours
QLD	Powerlink	06/12/2021 07:00 Monday	06/12/2021 16:00 Monday	Bouldercombe - Nebo (821) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 4 hrs Night: NA	Planned - SUBMIT				Commissioning 9 Hours
QLD	Powerlink	07/12/2021 07:00 Tuesday	07/12/2021 16:00 Tuesday	Bouldercombe - Nebo (821) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 4 hrs Night: NA	Planned - SUBMIT				Commissioning 9 Hours
TAS	TasNetworks	08/12/2021 07:00 Wednesday	08/12/2021 16:00 Wednesday	Gordon - Chapel St No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2 hrs Night: NA	Planned - SUBMIT		~		Maintenance 9 Hours
TAS	TasNetworks	09/12/2021 07:00 Thursday	09/12/2021 16:00 Thursday	Gordon - Chapel St No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2 hrs Night: NA	Planned - SUBMIT		~		Maintenance 9 Hours
TAS	TasNetworks	11/01/2022 07:00 Tuesday	11/01/2022 15:00 Tuesday	Gordon - Chapel St No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2 hrs Night: NA	Planned - SUBMIT		~		Commissioning 8 Hours
QLD	Powerlink	10/02/2022 09:00 Thursday	10/02/2022 14:00 Thursday	Ross No.4 288/138/19 kV Transformer	< <new last="" notification="" since="" the="">> This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.</new>	Day: 30 mins Night: NA	Planned - SUBMIT				Maintenance 5 Hours
TAS	TasNetworks	16/02/2022 07:00 Wednesday	18/02/2022 15:00 Friday	Gordon - Chapel St No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 48 hrs Night: 48 hrs	Planned - SUBMIT		~		Commissioning 2.3 Days
TAS	TasNetworks	24/02/2022 07:00 Thursday	24/02/2022 15:00 Thursday	Gordon - Chapel St No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 1 hr Night: NA	Planned - SUBMIT		~		Commissioning 8 Hours
VIC	AusNet	01/03/2022 06:00 Tuesday	01/03/2022 15:00 Tuesday	Red Cliffs-Wemen 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 4 hrs Night: NA	Planned - SUBMIT				Maintenance 9 Hours

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	Generator Aware?	Inter-Regional	Reason and Duration
VIC	AusNet	01/03/2022 06:00 Tuesday	01/03/2022 15:00 Tuesday	Buronga - Redcliffs (OX1) 220 kV Line.	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 4 hrs Night: NA	Planned - SUBMIT				Maintenance 9 Hours
VIC	AusNet	02/03/2022 06:00 Wednesday	02/03/2022 15:00 Wednesday	Red Cliffs-Wemen 220 kV Line	 This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: 4 hrs Night: NA	Planned - SUBMIT				Maintenance 9 Hours
VIC	AusNet	03/03/2022 06:00 Thursday	03/03/2022 15:00 Thursday	Red Cliffs-Wemen 220 kV Line	 This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: 4 hrs Night: NA	Planned - SUBMIT				Maintenance 9 Hours
VIC	AusNet	09/03/2022 06:00 Wednesday	09/03/2022 15:00 Wednesday	Buronga - Redcliffs (OX1) 220 kV Line.	 This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: 4 hrs Night: NA	Planned - SUBMIT				Maintenance 9 Hours
VIC	AusNet	10/03/2022 06:00 Thursday	10/03/2022 15:00 Thursday	Buronga - Redcliffs (OX1) 220 kV Line.	 This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: 4 hrs Night: NA	Planned - SUBMIT				Maintenance 9 Hours
VIC	AusNet	16/03/2022 06:00 Wednesday	16/03/2022 13:00 Wednesday	Buronga - Redcliffs (OX1) 220 kV Line.	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 4 hrs Night: NA	Planned - SUBMIT				Maintenance 7 Hours
QLD	Powerlink	22/03/2022 09:00 Tuesday	22/03/2022 17:00 Tuesday	Ross No.2 288/138/19 kV Transformer	< <new last="" notification="" since="" the="">> This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.</new>	Day: 3 hrs Night: NA	Planned - SUBMIT				Maintenance 8 Hours
TAS	TasNetworks	04/04/2022 08:00 Monday	06/04/2022 16:00 Wednesday	Gordon - Chapel St No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 48 hrs Night: 48 hrs	Planned - SUBMIT		~		Commissioning 2.3 Days

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	Generator Aware?	Inter-Regional	Reason and Duration
QLD	Powerlink	05/04/2022 10:35 Tuesday	05/04/2022 16:00 Tuesday	Strathmore - Ross (8857) 275 kV Line	< <new last="" notification="" since="" the="">> This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.</new>	Day: 1.5 hrs Night: NA	Planned - SUBMIT				Maintenance 5.4 Hours
VIC	AusNet	20/04/2022 07:00 Wednesday	20/04/2022 16:00 Wednesday	Buronga - Redcliffs (OX1) 220 kV Line.	 This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: 4 hrs Night: NA	Planned - SUBMIT				Maintenance 9 Hours
VIC	AusNet	10/05/2022 07:00 Tuesday	10/05/2022 16:00 Tuesday	Buronga - Redcliffs (OX1) 220 kV Line.	 This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: 4 hrs Night: NA	Planned - SUBMIT				Maintenance 9 Hours
QLD	Powerlink	10/05/2022 07:00 Tuesday	12/05/2022 17:00 Thursday	Bouldercombe - Nebo (821) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 6 hrs Night: 8 hrs	Planned - SUBMIT				Commissioning 2.4 Days
VIC	AusNet	11/05/2022 07:00 Wednesday	11/05/2022 16:00 Wednesday	Buronga - Redcliffs (OX1) 220 kV Line.	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 4 hrs Night: NA	Planned - SUBMIT				Maintenance 9 Hours
VIC	AusNet	12/05/2022 07:00 Thursday	12/05/2022 16:00 Thursday	Buronga - Redcliffs (OX1) 220 kV Line.	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 4 hrs Night: NA	Planned - SUBMIT				Maintenance 9 Hours
VIC	AusNet	13/05/2022 07:00 Friday	13/05/2022 16:00 Friday	Buronga - Redcliffs (OX1) 220 kV Line.	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 4 hrs Night: NA	Planned - SUBMIT				Maintenance 9 Hours
VIC	AusNet	17/05/2022 07:00 Tuesday	17/05/2022 16:00 Tuesday	Buronga - Redcliffs (OX1) 220 kV Line.	 This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: 4 hrs Night: NA	Planned - SUBMIT				Maintenance 9 Hours

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNSP Aware?	Inter-Regional	Reason and Duration
QLD	Powerlink	24/05/2022 07:00 Tuesday	03/06/2022 17:00 Friday	Bouldercombe - Broadsound (820) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 120 hrs Night: 120 hrs	Planned - SUBMIT				Commissioning 10.4 Days
VIC	AusNet	31/05/2022 07:00 Tuesday	31/05/2022 16:00 Tuesday	Buronga - Redcliffs (OX1) 220 kV Line.	 This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: 4 hrs Night: NA	Planned - SUBMIT				Maintenance 9 Hours
QLD	Powerlink	02/08/2022 07:00 Tuesday	22/08/2022 17:00 Monday	Nebo - Strathmore (8845) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: NA Night: NA	Planned - SUBMIT				Commissioning 20.4 Days
QLD	Powerlink	29/08/2022 07:00 Monday	16/09/2022 17:00 Friday	Nebo - Strathmore (878) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: NA Night: NA	Planned - SUBMIT				Commissioning 18.4 Days
QLD	Powerlink	13/09/2022 07:00 Tuesday	23/09/2022 17:00 Friday	Bouldercombe - Broadsound (820) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 120 hrs Night: 120 hrs	Planned - SUBMIT				Commissioning 10.4 Days
QLD	Powerlink	17/10/2022 07:00 Monday	03/11/2022 17:00 Thursday	Nebo - Strathmore (8845) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 24 hrs Night: 48 hrs	Planned - SUBMIT				Commissioning 17.4 Days
QLD	Powerlink	06/02/2023 17:01 Monday	03/03/2023 17:00 Friday	Strathmore No.1 275/132 kV Transformer	< <new last="" notification="" since="" the="">> This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.</new>	Day: NA Night: NA	Planned - SUBMIT				Commissioning 25 Days

The following fields of data are submitted by NSPs to AEMO.

✓ Unplanned - Outage is forced outage, trip or submitted with short notice.

✓ DNSP(s) Aware - The TNSP that submitted the outage confirms they have notified DNSP(s) that are impacted by this outage and made aware of the risks of next contingency.

✓ Generator(s) Aware - The TNSP that submitted the outage confirms they have notified generator(s) that are directly impacted by this outage and made aware of potential risks of next credible contingency.

✓ Inter-Regional - The TNSP that submitted the outage confirms they have notified other TNSP(s) that may be impacted by this outage, often in the neighbouring region.

Disclaimer

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice, and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the

National Electricity Rules, or any other applicable laws, procedures or policies. AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

* make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and

* are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.