

Upcoming High-Impact Outages (HIOs) in the NEM - Information Current as of: 27 November 2023 - 1012 hrs -

Legend Newly Added Outage Update(s) since the last notification Withdrawn since the last notification

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | uu | DNSP Aware? | Inter-Regional | Reason and |
|--------|-------------|-------------------------------|-------------------------------|---------------------------------------|--|---------------------------|-----------------------------|----|-------------|----------------|-----------------------------------|
| VIC | AusNet | 04/12/2023 08:30 Monday | 04/12/2023 09:00 Monday | Heywood No.2 500 kV Bus | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 1 hr Night: NA | Planned - SUBMIT | | | | Maintenance 30 Minutes |
| TAS | TasNetworks | 05/12/2023 06:30 Tuesday | 05/12/2023 15:00 Tuesday | Sheffield - Farrell No.1 220 kV Line | < <this been="" has="" outage="" withdrawn!="">> A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.</this> | Day: 2 hrs Night: NA | Withdrawn | | v | / | TAS Commissioning 8.5 Hours |
| TAS | TasNetworks | 06/12/2023 06:30 Wednesday | 06/12/2023 15:00 Wednesday | Sheffield - Farrell No.2 220 kV Line | < <this been="" has="" outage="" withdrawn!="">> A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.</this> | Day: 2 hrs Night: NA | Withdrawn | | V | / | TAS Commissioning 8.5 Hours |
| QLD | Powerlink | 06/12/2023 07:00 Wednesday | 06/12/2023 17:00 Wednesday | Bouldercombe - Nebo (821) 275 kV Line | < <new last="" notification="" since="" the="">> This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.</new> | Day: 2 hrs Night: NA | Planned - MTLTP | | | | QLD Commissioning 10 Hours |
| QLD | Powerlink | 07/12/2023 08:00 Thursday | 07/12/2023 13:59 Thursday | Bouldercombe - Nebo (821) 275 kV Line | < <new last="" notification="" since="" the="">> This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.</new> | Day: 30 mins Night: NA | Planned - MTLTP | | | | QLD Commissioning 6 Hours |
| TAS | TasNetworks | 08/12/2023 08:00 Friday | 08/12/2023 15:00 Friday | Sheffield - Farrell No.1 220 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.</new> | Day: 2 hrs Night: NA | Planned - RESUBMIT | | V | ′ ✓ | TAS Commissioning 7 Hours |
| TAS | TasNetworks | 09/12/2023 08:00 Saturday | 09/12/2023 15:00 Saturday | Sheffield - Farrell No.2 220 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.</new> | Day: 2 hrs Night: NA | Planned - RESUBMIT | | V | / | TAS Commissioning 7 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Av | Generator Aware? | Impact Region, Reason and Duration |
|--------|-------------|-------------------------------|-------------------------------|--|---|----------------------------|-----------------------------|------------|---------|------------------|--|
| TAS | TasNetworks | 18/12/2023 13:00 Monday | 18/12/2023 15:30 Monday | Gordon - Chapel St No.2 220 kV Line | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania. | Day: 1 hr Night: NA | Planned - MTLTP | | | ✓ | TAS Commissioning 2.5 Hours |
| VIC | AusNet | 31/12/2023 06:00 Sunday | 31/12/2023 16:00 Sunday | Hazelwood - Loy Yang Power Station No.2 500 kV Line | A credible contingency event during this planned outage could cause: • A large reduction in generation in Victoria • Load shedding in Victoria | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | VIC Maintenance 10 Hours |
| NSW | Transgrid | 09/01/2024 05:00 Tuesday | 09/01/2024 15:00 Tuesday | Tamworth - Uralla (85) 330 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM</new> | Day: 2 hrs Night: NA | Planned - MTLTP | | ✓ | ✓ | NSW / QLD Commissioning 10 Hours |
| QLD | Powerlink | 09/01/2024 08:30 Tuesday | 09/01/2024 11:00 Tuesday | Strathmore - Ross (8858) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 1 hr Night: NA | Planned - SUBMIT | | ✓ | | QLD Maintenance 2.5 Hours |
| NSW | Transgrid | 10/01/2024 05:00 Wednesday | 10/01/2024 15:00 Wednesday | Armidale - Uralla (8U) 330 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM</new> | Day: 2 hrs Night: NA | Planned - MTLTP | | | ✓ · | NSW / QLD Commissioning 10 Hours |
| NSW | Transgrid | 11/01/2024 05:00 Thursday | 11/01/2024 15:00 Thursday | Armidale - Sapphire WF (8E) 330 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM</new> | Day: 2 hrs Night: NA | Planned - MTLTP | | | ✓ · | NSW / QLD Commissioning 10 Hours |
| NSW | Transgrid | 12/01/2024 05:00 Friday | 12/01/2024 15:00 Friday | Armidale - Dumaresq (8C) 330 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM</new> | Day: 2 hrs Night: NA | Planned - MTLTP | | | | NSW / QLD Commissioning 10 Hours |
| TAS | TasNetworks | 22/01/2024 07:00 Monday | 22/01/2024 11:00 Monday | Sheffield - Farrell No.1 220 kV Line | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania. | Day: 30 mins Night: NA | Planned - SUBMIT | | | ✓ | TAS Commissioning 4 Hours |
| TAS | TasNetworks | 30/01/2024 07:00 Tuesday | 02/02/2024 11:00 Friday | Sheffield - Farrell No.1 220 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.</new> | Day: 4 hrs Night: 4 hrs | Planned - SUBMIT | | | ✓ | TAS Commissioning 3.2 Days |
| QLD | Powerlink | 01/02/2024 07:30 Thursday | 01/02/2024 17:00 Thursday | Nebo - Strathmore (8845) 275 kV Line | < <new last="" notification="" since="" the="">> This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.</new> | Day: 4 hrs Night: NA | Planned - SUBMIT | | | √ | QLD Maintenance 9.5 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | | Generator Aware? | Impact Region, Reason and Duration |
|--------|-----------|------------------------------|------------------------------|--------------------------------------|---|------------------------------|-----------------------------|------------|---|------------------|---------------------------------------|
| QLD | Powerlink | 08/02/2024 08:00 Thursday | 09/02/2024 16:00 Friday | Strathmore - Ross (8858) 275 kV Line | < <this been="" has="" outage="" withdrawn!="">> This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.</this> | Day: 5 hrs Night: 8 hrs | Withdrawn | | | ✓ | QLD Commissioning 1.3 Days |
| QLD | Powerlink | 08/02/2024 08:00 Thursday | 09/02/2024 16:00 Friday | Strathmore - Ross (8858) 275 kV Line | < <new last="" notification="" since="" the="">> This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.</new> | Day: 5 hrs Night: 8 hrs | Planned - SUBMIT | | | ✓ | QLD Commissioning 1.3 Days |
| QLD | Powerlink | 13/02/2024 08:00 Tuesday | 15/02/2024 13:00 Thursday | Strathmore - Ross (8857) 275 kV Line | < <new last="" notification="" since="" the="">> This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | ✓ | QLD Commissioning 2.2 Days |
| QLD | Powerlink | 04/03/2024 08:00 Monday | 08/03/2024 17:00 Friday | Nebo - Strathmore (822) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 48 hrs Night: 48 hrs | Planned - SUBMIT | | | | QLD Maintenance 4.4 Days |
| VIC | AusNet | 05/03/2024 06:00 Tuesday | 05/03/2024 15:00 Tuesday | Hazelwood - Rowville 500 kV Line | < <new last="" notification="" since="" the="">> This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | VIC Maintenance 9 Hours |
| NSW | Transgrid | 07/03/2024 06:00 Thursday | 12/03/2024 16:00 Tuesday | Jindera - Wagga (62) 330 kV Line | < <new last="" notification="" since="" the="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer Between Victoria and New South Wales. Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. </new> | Day: 6 hrs Night: 8 hrs | Planned - SUBMIT | | ✓ | ✓ | NSW/ VIC Commissioning 5.4 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | | ᇑ | Impact Region, Reason and Duration |
|--------|-------------|-----------------------------|------------------------------|--|---|----------------------------|-----------------------------|------------|---|-----|---|
| NSW | Transgrid | 10/03/2024 07:00 Sunday | 10/03/2024 15:00 Sunday | Buronga-Balranald (X3) 220kV line | < <new last="" notification="" since="" the="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C During this planned outage power transfer will be restricted • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.</new> | Day: 4 hrs Night: NA | Planned - RESUBMIT | | ✓ | ✓ . | NSW/VIC/SA Commissioning 8 Hours |
| TAS | TasNetworks | 11/03/2024 07:00 Monday | 14/03/2024 15:00 Thursday | Sheffield - Farrell No.1 220 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.</new> | Day: 4 hrs Night: 6 hrs | Planned - SUBMIT | | | ✓ | TAS Commissioning 3.3 Days |
| TAS | TasNetworks | 18/03/2024 07:00 Monday | 18/03/2024 11:00 Monday | Sheffield - Farrell No.1 220 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.</new> | Day: 1 hr Night: NA | Planned - SUBMIT | | | ✓ | TAS Commissioning 4 Hours |
| QLD | Powerlink | 18/03/2024 08:00 Monday | 18/03/2024 15:30 Monday | Broadsound - Nebo (834) 275 kV Line | < <this been="" has="" outage="" withdrawn!="">> This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.</this> | Day: 2 hrs Night: NA | Withdrawn | | | | QLD Maintenance 7.5 Hours |
| VIC | AusNet | 18/03/2024 09:00 Monday | 18/03/2024 10:00 Monday | Red Cliffs No.2 220 kV Bus | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This bus outage offloads Red Cliffs - Kiamal 220kV line, and Red Cliffs capacitor banks will be unavailable for automatic switching. A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. | Day: 30 mins Night: NA | Planned - SUBMIT | | | | VIC Maintenance 60 Minutes |
| VIC | AusNet | 19/03/2024 06:00 Tuesday | 01/04/2024 16:00 Monday | Buronga - Redcliffs (OX1) 220 kV Line. | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: NA Night: NA | Planned - SUBMIT | | | | NSW / VIC Commissioning 13.4 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? | Inter-Regional | |
|--------|-----------|------------------------------|------------------------------|--------------------------------------|--|-------------------------|-----------------------------|------------|-------------|----------------|-------------------------------------|
| VIC | AusNet | 21/03/2024 05:00 Thursday | 21/03/2024 17:00 Thursday | Red Cliffs No.2 220 kV Bus | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This bus outage offloads Red Cliffs - Kiamal 220kV line, and Red Cliffs capacitor banks will be unavailable for automatic switching. A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | VIC Maintenance 12 Hours |
| QLD | Powerlink | 22/03/2024 07:00 Friday | 22/03/2024 16:00 Friday | Strathmore - Ross (8857) 275 kV Line | < <new last="" notification="" since="" the="">> This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.</new> | Day: 3 hrs Night: NA | Planned - SUBMIT | | ✓ | | QLD Commissioning 9 Hours |
| VIC | AusNet | 23/03/2024 06:00 Saturday | 23/03/2024 18:00 Saturday | Jindera - Wodonga (060) 330 kV Line | < <new last="" notification="" since="" the="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer Between Victoria and New South Wales. Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. </new> | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | NSW/ VIC Maintenance 12 Hours |
| VIC | AusNet | 24/03/2024 06:00 Sunday | 24/03/2024 18:00 Sunday | Jindera - Wodonga (060) 330 kV Line | < <new last="" notification="" since="" the="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.</new> | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | NSW/ VIC Maintenance 12 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? | Generator Aware? | Impact Region and Duration | nd |
|--------|-----------|-------------------------------|-------------------------------|--|--|----------------------------|-----------------------------|------------|-------------|------------------|------------------------------------|----|
| VIC | AusNet | 25/03/2024 06:00 Monday | 25/03/2024 18:00 Monday | Jindera - Wodonga (060) 330 kV Line | < <new last="" notification="" since="" the="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer Between Victoria and New South Wales. Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. </new> | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | NSW/ VIC Maintenand 12 Hours | ce |
| QLD | Powerlink | 27/03/2024 09:30 Wednesday | | Haughton River - Strathmore (879) 275 kV Line | < <new last="" notification="" since="" the="">> This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.</new> | Day: 1 hr Night: NA | Planned - SUBMIT | | ✓ | ✓ | QLD Maintenand 4.5 Hours | |
| QLD | Powerlink | 02/04/2024 08:00 Tuesday | 19/04/2024 17:00 Friday | Nebo - Strathmore (8845) 275 kV Line | < <new last="" notification="" since="" the="">> This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.</new> | Day: 3 hrs Night: 5 hrs | Planned - SUBMIT | | ✓ | ✓ | Maintenand 17.4 Days | |
| VIC | AusNet | 03/04/2024 06:00 Wednesday | 03/04/2024 15:00 Wednesday | Buronga - Redcliffs (OX1) 220 kV Line. | < <new last="" notification="" since="" the="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. </new> | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | NSW / VIC Maintenanc 9 Hours | ce |
| VIC | AusNet | 04/04/2024 06:00 Thursday | 04/04/2024 15:00 Thursday | Buronga - Redcliffs (OX1) 220 kV Line. | < <new last="" notification="" since="" the="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. </new> | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | NSW / VIC Maintenand 9 Hours | ce |
| VIC | AusNet | 09/04/2024 07:00 Tuesday | 09/04/2024 17:00 Tuesday | Hazelwood - South Morang No.2 500 kV Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | VIC Maintenand 10 Hours | |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? | Inter-Regional | Impact Region, Reason and Duration |
|--------|--------|-------------------------------|-------------------------------|--|---|-------------------------|-----------------------------|------------|-------------|----------------|--|
| VIC | AusNet | 10/04/2024 07:00 Wednesday | 10/04/2024 17:00 Wednesday | Hazelwood - South Morang No.2 500 kV Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | VIC Maintenance 10 Hours |
| VIC | AusNet | 11/04/2024 07:30 Thursday | | Hazelwood - South Morang No.1 500 kV Line | < <new last="" notification="" since="" the="">> This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | VIC Maintenance 9.5 Hours |
| VIC | AusNet | 12/04/2024 07:30 Friday | 12/04/2024 17:00 Friday | Hazelwood - South Morang No.1 500 kV Line | < <new last="" notification="" since="" the="">> This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | VIC Maintenance 9.5 Hours |
| VIC | AusNet | 16/04/2024 07:00 Tuesday | 16/04/2024 16:00 Tuesday | Buronga - Redcliffs (OX1) 220 kV Line. | < <new last="" notification="" since="" the="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.</new> | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | NSW / VIC Maintenance 9 Hours |
| VIC | AusNet | 18/04/2024 07:30 Thursday | 19/04/2024 17:00 Friday | Hazelwood - Rowville 500 kV Line | < <new last="" notification="" since="" the="">> This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | VIC Maintenance 1.4 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? | Inter-Regional | Impact Region, Reason and Duration |
|--------|--------|-------------------------------|-------------------------------|---------------------------------------|---|-------------------------|-----------------------------|------------|-------------|----------------|--|
| VIC | AusNet | 29/04/2024 07:00 Monday | 29/04/2024 17:00 Monday | Jindera - Wodonga (060) 330 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | NSW/ VIC Maintenance 10 Hours |
| VIC | AusNet | 30/04/2024 07:00 Tuesday | 30/04/2024 17:00 Tuesday | Jindera - Wodonga (060) 330 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | NSW/ VIC Maintenance 10 Hours |
| VIC | AusNet | 07/05/2024 06:00 Tuesday | 07/05/2024 18:00 Tuesday | Moorabool - Haunted Gully 500 kV line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 08/05/2024 06:00 Wednesday | 08/05/2024 18:00 Wednesday | Moorabool - Haunted Gully 500 kV line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? | Inter-Regional | Impact Region, Reason and Duration |
|--------|--------|------------------------------|------------------------------|---------------------------------------|---|-------------------------|-----------------------------|------------|-------------|----------------|--|
| VIC | AusNet | 09/05/2024 06:00 Thursday | 09/05/2024 18:00 Thursday | Moorabool - Haunted Gully 500 kV line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 10/05/2024 06:00 Friday | 10/05/2024 18:00 Friday | Moorabool - Haunted Gully 500 kV line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 11/05/2024 06:00 Saturday | 11/05/2024 18:00 Saturday | Moorabool - Haunted Gully 500 kV line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 12/05/2024 06:00 Sunday | 12/05/2024 18:00 Sunday | Moorabool - Haunted Gully 500 kV line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? | Inter-Regional | Impact Region, Reason and Duration |
|--------|--------|-------------------------------|-------------------------------|---------------------------------------|---|-------------------------|-----------------------------|------------|-------------|----------------|--|
| VIC | AusNet | 13/05/2024 06:00 Monday | 13/05/2024 18:00 Monday | Moorabool - Haunted Gully 500 kV line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 14/05/2024 06:00 Tuesday | 14/05/2024 18:00 Tuesday | Moorabool - Haunted Gully 500 kV line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 15/05/2024 06:00 Wednesday | 15/05/2024 18:00 Wednesday | Moorabool - Haunted Gully 500 kV line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 16/05/2024 06:00 Thursday | 16/05/2024 18:00 Thursday | Moorabool - Haunted Gully 500 kV line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? Generator Aware? | Inter-Regional | Impact Region, Reason and Duration |
|--------|------------|------------------------------|------------------------------|--|--|-----------------------------|-----------------------------|------------|---------------------------------|----------------|--|
| VIC | AusNet | 16/05/2024 07:00 Thursday | 16/05/2024 16:00 Thursday | Buronga - Redcliffs (OX1) 220 kV Line. | < <new last="" notification="" since="" the="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions.</new> | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | NSW / VIC Maintenance 9 Hours |
| VIC | AusNet | 17/05/2024 06:00 Friday | 17/05/2024 18:00 Friday | Moorabool - Haunted Gully 500 kV line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| SA | ElectraNet | 20/05/2024 07:30 Monday | 26/05/2024 19:30 Sunday | Heywood - South East No.1 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | ✓ | VIC / SA Maintenance 6.5 Days |
| VIC | AusNet | 21/05/2024 06:00 Tuesday | 21/05/2024 18:00 Tuesday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? | Inter-Regional | Impact Region, Reason and Duration |
|--------|--------|-------------------------------|-------------------------------|----------------------------------|---|-------------------------|-----------------------------|------------|-------------|----------------|--|
| VIC | AusNet | 22/05/2024 06:00 Wednesday | 22/05/2024 18:00 Wednesday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 23/05/2024 06:00 Thursday | 23/05/2024 18:00 Thursday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 24/05/2024 06:00 Friday | 24/05/2024 18:00 Friday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 25/05/2024 06:00 Saturday | 25/05/2024 18:00 Saturday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Av | Generator Aware? Inter-Regional | Impact Region, Reason and Duration |
|--------|------------|-----------------------------|-----------------------------|---------------------------------------|--|-----------------------------|-----------------------------|------------|---------|------------------------------------|-------------------------------------|
| VIC | AusNet | 26/05/2024 06:00 Sunday | 26/05/2024 18:00 Sunday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 27/05/2024 06:00 Monday | 27/05/2024 18:00 Monday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| SA | ElectraNet | 27/05/2024 07:30 Monday | 02/06/2024 17:30 Sunday | Heywood - South East No.2 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | ✓ | VIC / SA Maintenance 6.4 Days |
| VIC | AusNet | 28/05/2024 06:00 Tuesday | 28/05/2024 18:00 Tuesday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? | Inter-Regional | Impact Region, Reason and Duration |
|--------|--------|-------------------------------|-------------------------------|----------------------------------|---|-------------------------|-----------------------------|------------|-------------|----------------|--|
| VIC | AusNet | 29/05/2024 06:00 Wednesday | 29/05/2024 18:00 Wednesday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 30/05/2024 06:00 Thursday | 30/05/2024 18:00 Thursday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 31/05/2024 06:00 Friday | 31/05/2024 18:00 Friday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 01/06/2024 06:00 Saturday | 01/06/2024 18:00 Saturday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? | Inter-Regional | Impact Region, Reason and Duration |
|--------|------------|----------------------------|----------------------------|---|---|-----------------------------|-----------------------------|------------|-------------|----------------|--|
| VIC | AusNet | 02/06/2024 06:00 Sunday | 02/06/2024 18:00 Sunday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 03/06/2024 06:00 Monday | 03/06/2024 18:00 Monday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 03/06/2024 07:00 Monday | 03/06/2024 17:00 Monday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 10 Hours |
| SA | ElectraNet | 03/06/2024 07:30 Monday | 09/06/2024 17:30 Sunday | Tailem Bend - South East No.1 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | Maintenance 6.4 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? Generator Aware? | Inter-Regional | Impact Region, Reason and Duration |
|--------|--------|-------------------------------|-------------------------------|----------------------------------|--|-------------------------|-----------------------------|------------|---------------------------------|----------------|--|
| VIC | AusNet | 04/06/2024 06:00 Tuesday | 04/06/2024 18:00 Tuesday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 04/06/2024 06:00 Tuesday | 04/06/2024 18:00 Tuesday | Heywood - Mortlake 500 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 05/06/2024 06:00 Wednesday | 05/06/2024 18:00 Wednesday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 05/06/2024 06:00 Wednesday | 05/06/2024 18:00 Wednesday | Moorabool - Mortlake 500 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? | Inter-Reg | Impact Region, Reason and Duration |
|--------|------------|------------------------------|------------------------------|---|---|-----------------------------|-----------------------------|------------|-------------|-----------|--|
| VIC | AusNet | 06/06/2024 06:00 Thursday | 06/06/2024 18:00 Thursday | Heywood - Mortlake 500 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 10/06/2024 07:00 Monday | 10/06/2024 17:00 Monday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 1 hr Night: NA | Planned - SUBMIT | | | | VIC Maintenance 10 Hours |
| SA | ElectraNet | 10/06/2024 07:30 Monday | 16/06/2024 17:30 Sunday | Tailem Bend - South East No.2 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | Maintenance 6.4 Days |
| VIC | AusNet | 17/06/2024 07:00 Monday | 17/06/2024 16:00 Monday | Buronga - Redcliffs (OX1) 220 kV Line. | < <new last="" notification="" since="" the="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.</new> | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | NSW / VIC Maintenance 9 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? | Inter-Regional | Reason and |
|--------|------------|-----------------------------|------------------------------|--|---|------------------------------|-----------------------------|------------|-------------|----------------|-------------------------------------|
| SA | ElectraNet | 17/06/2024 07:30 Monday | 23/06/2024 17:30 Sunday | Tailem Bend - Tungkillo No.1 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | SA Maintenance 6.4 Days |
| VIC | AusNet | 18/06/2024 06:30 Tuesday | 18/06/2024 17:00 Tuesday | Red Cliffs-Wemen 220 kV Line | < <new last="" notification="" since="" the="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.</new> | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | VIC Maintenance 10.5 Hours |
| VIC | AusNet | 18/06/2024 07:00 Tuesday | 18/06/2024 16:00 Tuesday | Buronga - Redcliffs (OX1) 220 kV Line. | < <new last="" notification="" since="" the="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.</new> | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | NSW / VIC Maintenance 9 Hours |
| SA | ElectraNet | 18/06/2024 09:00 Tuesday | 20/06/2024 16:30 Thursday | Tailem Bend - Tungkillo No.2 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 48 hrs Night: 48 hrs | Planned - SUBMIT | | | | Maintenance 2.3 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? | Impact Region, Reason and Duration |
|--------|------------|-------------------------------|-------------------------------|--|---|------------------------------|-----------------------------|------------|-------------|--|
| VIC | AusNet | 19/06/2024 07:00 Wednesday | 19/06/2024 16:00 Wednesday | Buronga - Redcliffs (OX1) 220 kV Line. | < <new last="" notification="" since="" the="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. </new> | Day: 4 hrs Night: NA | Planned - SUBMIT | | | NSW / VIC Maintenance 9 Hours |
| VIC | AusNet | 19/06/2024 07:00 Wednesday | 19/06/2024 17:00 Wednesday | Red Cliffs-Wemen 220 kV Line | < <new last="" notification="" since="" the="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. </new> | Day: 2 hrs Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours |
| VIC | AusNet | 20/06/2024 07:00 Thursday | 20/06/2024 17:00 Thursday | Red Cliffs-Wemen 220 kV Line | < <new last="" notification="" since="" the="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. </new> | Day: 2 hrs Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours |
| VIC | AusNet | 20/06/2024 07:00 Thursday | 20/06/2024 16:00 Thursday | Buronga - Redcliffs (OX1) 220 kV Line. | < <new last="" notification="" since="" the="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. </new> | Day: 4 hrs Night: NA | Planned - SUBMIT | | | NSW / VIC Maintenance 9 Hours |
| SA | ElectraNet | 20/06/2024 16:30 Thursday | 22/06/2024 16:30 Saturday | Tailem Bend - Tungkillo No.2 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 48 hrs Night: 48 hrs | Planned - SUBMIT | | | Maintenance 2 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? | Inter-Regional | Reason and |
|--------|------------|-----------------------------|-----------------------------|--|---|-----------------------------|-----------------------------|------------|-------------|----------------|-------------------------------------|
| VIC | AusNet | 21/06/2024 07:00 Friday | 21/06/2024 16:00 Friday | Buronga - Redcliffs (OX1) 220 kV Line. | < <new last="" notification="" since="" the="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.</new> | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | NSW / VIC Maintenance 9 Hours |
| SA | ElectraNet | 24/06/2024 07:30 Monday | 30/06/2024 17:30 Sunday | Tailem Bend - Tungkillo No.2 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | SA Maintenance 6.4 Days |
| QLD | Powerlink | 24/06/2024 08:00 Monday | 28/06/2024 16:00 Friday | Nebo - Strathmore (822) 275 kV Line | < <new last="" notification="" since="" the="">> This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.</new> | Day: 2 hrs Night: 6 hrs | Planned - SUBMIT | | | | QLD Commissioning 4.3 Days |
| VIC | AusNet | 25/06/2024 06:00 Tuesday | 25/06/2024 21:00 Tuesday | Moorabool - Mortlake 500 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 15 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? Generator Aware? | Inter-Regional | Impact Region, Reason and Duration |
|--------|------------|------------------------------|------------------------------|--|---|------------------------------|-----------------------------|------------|---------------------------------|----------------|--|
| VIC | AusNet | 27/06/2024 06:00 Thursday | 27/06/2024 21:00 Thursday | Moorabool - Mortlake 500 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 15 Hours |
| SA | ElectraNet | 29/06/2024 05:30 Saturday | 29/06/2024 11:00 Saturday | Tailem Bend - Tungkillo No.2 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 48 hrs Night: 48 hrs | Planned - SUBMIT | | | | Maintenance 5.5 Hours |
| VIC | AusNet | 01/07/2024 06:00 Monday | 01/07/2024 21:00 Monday | Moorabool - Mortlake 500 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 15 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | Generator Aware? Inter-Regional | Impact Region, Reason and Duration |
|--------|--------|-------------------------------|-------------------------------|---------------------------------------|--|-------------------------|-----------------------------|------------|------------------------------------|--|
| VIC | AusNet | 02/07/2024 06:00 Tuesday | 02/07/2024 18:00 Tuesday | Moorabool - Haunted Gully 500 kV line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 03/07/2024 07:00 Wednesday | 03/07/2024 17:00 Wednesday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | VIC / SA Maintenance 10 Hours |
| VIC | AusNet | 05/07/2024 06:00 Friday | 05/07/2024 21:00 Friday | Moorabool - Mortlake 500 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 2 hrs Night: NA | Planned - SUBMIT | | | VIC / SA Maintenance 15 Hours |
| VIC | AusNet | 09/07/2024 07:00 Tuesday | 09/07/2024 17:00 Tuesday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | VIC / SA Maintenance 10 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Av | Generator Aware? Inter-Regional | Impact Region, Reason and Duration |
|--------|-----------|-------------------------------|-------------------------------|--|---|--------------------------|-----------------------------|------------|---------|------------------------------------|--|
| VIC | AusNet | 10/07/2024 06:00 Wednesday | 10/07/2024 18:00 Wednesday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 10/07/2024 07:00 Wednesday | 10/07/2024 16:00 Wednesday | Buronga - Redcliffs (OX1) 220 kV Line. | < <new last="" notification="" since="" the="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. </new> | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | NSW / VIC Maintenance 9 Hours |
| VIC | AusNet | 22/08/2024 07:00 Thursday | 22/08/2024 18:00 Thursday | Moorabool–Sydenham No.1 500 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage may require market intervention through issuing of directions</new> | Day: 60 hrs Night: NA | Planned - SUBMIT | | | | VIC Maintenance 11 Hours |
| VIC | AusNet | 23/08/2024 07:00 Friday | 23/08/2024 18:00 Friday | Moorabool–Sydenham No.1 500 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage may require market intervention through issuing of directions</new> | Day: 60 hrs Night: NA | Planned - SUBMIT | | | | VIC Maintenance 11 Hours |
| VIC | AusNet | 31/08/2024 07:00 Saturday | 31/08/2024 18:00 Saturday | Moorabool–Sydenham No.2 500 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage may require market intervention through issuing of directions</new> | Day: 60 hrs Night: NA | Planned - SUBMIT | | | | VIC Maintenance 11 Hours |
| VIC | AusNet | 01/09/2024 07:00 Sunday | 01/09/2024 18:00 Sunday | Moorabool–Sydenham No.2 500 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage may require market intervention through issuing of directions</new> | Day: 60 hrs Night: NA | Planned - SUBMIT | | | | VIC Maintenance 11 Hours |
| NSW | Transgrid | 09/09/2024 05:30 Monday | 09/09/2024 22:00 Monday | Balranald - Darlington Point (X5) 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C During this planned outage power transfer will be restricted • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 12 hrs Night: NA | Planned - SUBMIT | | | √ √ | NSW / VIC Commissioning 16.5 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? | Inter-Regional | Reason and |
|--------|-------------|-------------------------------|------------------------------|---|---|---------------------------|-----------------------------|------------|-------------|----------------|---|
| VIC | AusNet | 10/09/2024 07:00 Tuesday | 12/09/2024 18:00 Thursday | South Morang - Sydenham No.1 500 kV Line | < <new last="" notification="" since="" the="">> This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 60 hrs Night: NA | Planned - SUBMIT | | | | VIC Maintenance 2.5 Days |
| TAS | TasNetworks | 17/09/2024 14:00 Tuesday | 17/09/2024 16:30 Tuesday | Gordon - Chapel St No.1 220 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.</new> | Day: 1 hr Night: NA | Planned - RESUBMIT | | ~ | , | TAS Maintenance 2.5 Hours |
| VIC | AusNet | 24/09/2024 07:00 Tuesday | 26/09/2024 18:00 Thursday | South Morang - Sydenham No.2 500 kV Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 24 hrs Night: NA | Planned - SUBMIT | | | | VIC Maintenance 2.5 Days |
| NSW | Transgrid | 30/09/2024 05:30 Monday | 30/09/2024 22:00 Monday | Jindera - Wagga (62) 330 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 12 hrs Night: NA | Planned - SUBMIT | | | | NSW/ VIC Commissioning 16.5 Hours |
| QLD | Powerlink | 09/10/2024 07:00 Wednesday | 21/10/2024 17:00 Monday | Strathmore - Ross (8858) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 72 hrs Night: NA | Planned - SUBMIT | | | | QLD Commissioning 12.4 Days |
| VIC | AusNet | 15/10/2024 06:00 Tuesday | 20/10/2024 17:00 Sunday | South Morang - Sydenham No.1 500 kV Line | < <new last="" notification="" since="" the="">> This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 120 hrs Night: NA | Planned - SUBMIT | | | | VIC Maintenance 5.5 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? Generator Aware? | | Impact Region, Reason and Duration |
|--------|------------|-------------------------------|------------------------------|---|--|------------------------------|-----------------------------|------------|---------------------------------|----------|--|
| VIC | AusNet | 01/11/2024 06:00 Friday | 01/11/2024 16:00 Friday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | VIC Maintenance 10 Hours |
| QLD | Powerlink | 25/11/2024 08:00 Monday | 29/11/2024 17:00 Friday | Nebo - Strathmore (822) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 48 hrs Night: 48 hrs | Planned - SUBMIT | | | | QLD Maintenance 4.4 Days |
| QLD | Powerlink | 03/03/2025 08:00 Monday | 07/03/2025 17:00 Friday | Nebo - Strathmore (822) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 48 hrs Night: 48 hrs | Planned - SUBMIT | | | | QLD Maintenance 4.4 Days |
| QLD | Powerlink | 07/03/2025 17:01 Friday | 19/08/2025 07:59 Tuesday | Nebo - Strathmore (822) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 0 mins Night: NA | Planned - SUBMIT | | | | QLD Maintenance 164.6 Days |
| VIC | AusNet | 05/04/2025 06:00 Saturday | 10/04/2025 17:00 Thursday | South Morang - Sydenham No.2 500 kV Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 120 hrs Night: NA | Planned - SUBMIT | | | | VIC Maintenance 5.5 Days |
| QLD | Powerlink | 23/04/2025 08:00 Wednesday | 09/05/2025 17:00 Friday | Strathmore - Ross (8858) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 72 hrs Night: NA | Planned - SUBMIT | | | | QLD Commissioning 16.4 Days |
| SA | ElectraNet | 19/05/2025 07:30 Monday | 25/05/2025 19:30 Sunday | Heywood - South East No.1 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | √ | Maintenance 6.5 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? Generator Aware? | Inter-Regional | Impact Region, Reason and Duration |
|--------|------------|----------------------------|----------------------------|---|---|-----------------------------|-----------------------------|------------|---------------------------------|----------------|--|
| SA | ElectraNet | 26/05/2025 07:30 Monday | 01/06/2025 17:30 Sunday | Heywood - South East No.2 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | ✓ | Maintenance 6.4 Days |
| SA | ElectraNet | 02/06/2025 07:30 Monday | 08/06/2025 17:30 Sunday | Tailem Bend - South East No.1 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | SA Maintenance 6.4 Days |
| SA | ElectraNet | 09/06/2025 07:30 Monday | 15/06/2025 17:30 Sunday | Tailem Bend (6595) 275 kV Circuit Breaker | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | Maintenance 6.4 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? | Generator Awarer Inter-Regional | Impact Region, Reason and Duration |
|--------|------------|-----------------------------|-------------------------------|---|---|-----------------------------|-----------------------------|------------|-------------|------------------------------------|--|
| SA | ElectraNet | 16/06/2025 07:30 Monday | 22/06/2025 17:30 Sunday | Tailem Bend (6536) 275 kV Circuit Breaker | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | Maintenance 6.4 Days |
| SA | ElectraNet | 23/06/2025 07:30 Monday | 29/06/2025 17:30 Sunday | Tailem Bend - Tungkillo No.2 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | SA Maintenance 6.4 Days |
| VIC | AusNet | 24/06/2025 07:00 Tuesday | 29/06/2025 17:00 Sunday | South Morang - Sydenham No.1 500 kV Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 120 hrs Night: NA | Planned - SUBMIT | | | | VIC Maintenance 5.4 Days |
| VIC | AusNet | 15/07/2025 07:00 Tuesday | 20/07/2025 17:00 Sunday | Moorabool–Sydenham No.1 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 120 hrs Night: NA | Planned - SUBMIT | | | | VIC Maintenance 5.4 Days |
| VIC | AusNet | 08/08/2025 07:00 Friday | 13/08/2025 17:00 Wednesday | South Morang - Sydenham No.2 500 kV Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 120 hrs Night: NA | Planned - SUBMIT | | | | VIC Maintenance 5.4 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? | Inter-Regional | Impact Region, Reason and Duration |
|--------|------------|------------------------------|-------------------------------|---------------------------------------|--|------------------------------|-----------------------------|-------------------|-------------|----------------|--|
| QLD | Powerlink | 19/08/2025 08:00 Tuesday | 24/11/2025 07:59 Monday | Nebo - Strathmore (822) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 0 mins Night: NA | Planned - SUBMIT | | | | QLD Maintenance 97 Days |
| VIC | AusNet | 01/09/2025 07:00 Monday | 06/09/2025 17:00 Saturday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 120 hrs Night: NA | Planned - SUBMIT | | | | VIC Maintenance 5.4 Days |
| QLD | Powerlink | 02/09/2025 08:00 Tuesday | 15/09/2025 17:00 Monday | Strathmore - Ross (8858) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: NA Night: NA | Planned - SUBMIT | | | | QLD Commissioning 13.4 Days |
| QLD | Powerlink | 03/11/2025 07:00 Monday | 07/11/2025 15:00 Friday | Nebo - Broadsound (8846) 275 kV Line | < <new last="" notification="" since="" the="">> This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.</new> | Day: 8 hrs Night: 8 hrs | Planned - SUBMIT | | | | QLD Commissioning 4.3 Days |
| QLD | Powerlink | 24/11/2025 08:00 Monday | 28/11/2025 17:00 Friday | Nebo - Strathmore (822) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 48 hrs Night: 48 hrs | Planned - SUBMIT | | | | QLD Maintenance 4.4 Days |
| QLD | Powerlink | 25/12/2025 08:00 Thursday | 07/01/2026 17:00 Wednesday | Strathmore - Ross (8858) 275 kV Line | < <new last="" notification="" since="" the="">> This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.</new> | Day: 72 hrs Night: NA | Planned - SUBMIT | | | | QLD Commissioning 13.4 Days |
| SA | ElectraNet | 18/05/2026 07:30 Monday | 24/05/2026 19:30 Sunday | Heywood - South East No.1 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | ✓ | Maintenance 6.5 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? Generator Aware? | Inter-Regional | Impact Region, Reason and Duration |
|--------|------------|----------------------------|----------------------------|---|---|-----------------------------|-----------------------------|------------|---------------------------------|----------------|--|
| SA | ElectraNet | 25/05/2026 07:30 Monday | 31/05/2026 17:30 Sunday | Heywood - South East No.2 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | ✓ | Maintenance 6.4 Days |
| SA | ElectraNet | 01/06/2026 07:30 Monday | 07/06/2026 17:30 Sunday | Tailem Bend - South East No.1 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | Maintenance 6.4 Days |
| SA | ElectraNet | 08/06/2026 07:30 Monday | 14/06/2026 17:30 Sunday | Tailem Bend (6595) 275 kV Circuit Breaker | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | Maintenance 6.4 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? Generator Aware? | Inter-Regional | Impact Region, Reason and Duration |
|--------|------------|----------------------------|----------------------------|---|---|-----------------------------|-----------------------------|------------|---------------------------------|----------------|--|
| SA | ElectraNet | 15/06/2026 07:30 Monday | 21/06/2026 17:30 Sunday | Tailem Bend (6536) 275 kV Circuit Breaker | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | SA Maintenance 6.4 Days |
| SA | ElectraNet | 22/06/2026 07:30 Monday | 28/06/2026 17:30 Sunday | Tailem Bend - Tungkillo No.2 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | SA Maintenance 6.4 Days |
| SA | ElectraNet | 17/05/2027 07:30 Monday | 23/05/2027 19:30 Sunday | Heywood - South East No.1 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | √ | Maintenance 6.5 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? Generator Aware? | Inter-Regional | Impact Region, Reason and Duration |
|--------|------------|----------------------------|----------------------------|---|---|-----------------------------|-----------------------------|------------|---------------------------------|----------------|--|
| SA | ElectraNet | 24/05/2027 07:30 Monday | 30/05/2027 17:30 Sunday | Heywood - South East No.2 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | ✓ | VIC / SA Maintenance 6.4 Days |
| SA | ElectraNet | 31/05/2027 07:30 Monday | 06/06/2027 17:30 Sunday | Tailem Bend - South East No.1 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | Maintenance 6.4 Days |
| SA | ElectraNet | 07/06/2027 07:30 Monday | 13/06/2027 17:30 Sunday | Tailem Bend (6595) 275 kV Circuit Breaker | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | Maintenance 6.4 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? Generator Aware? | Inter-Regional | Impact Region, Reason and Duration |
|--------|------------|----------------------------|----------------------------|---|---|-----------------------------|-----------------------------|------------|---------------------------------|----------------|--|
| SA | ElectraNet | 14/06/2027 07:30 Monday | 20/06/2027 17:30 Sunday | Tailem Bend (6536) 275 kV Circuit Breaker | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | SA Maintenance 6.4 Days |
| SA | ElectraNet | 21/06/2027 07:30 Monday | 27/06/2027 17:30 Sunday | Tailem Bend - Tungkillo No.2 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | Maintenance 6.4 Days |
| SA | ElectraNet | 22/05/2028 07:30 Monday | 28/05/2028 19:30 Sunday | Heywood - South East No.1 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | ✓ | Maintenance 6.5 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? Generator Aware? | Inter-Regional | Impact Region, Reason and Duration |
|--------|------------|----------------------------|----------------------------|---|---|-----------------------------|-----------------------------|------------|---------------------------------|----------------|--|
| SA | ElectraNet | 29/05/2028 07:30 Monday | 04/06/2028 17:30 Sunday | Heywood - South East No.2 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | * | VIC / SA Maintenance 6.4 Days |
| SA | ElectraNet | 05/06/2028 07:30 Monday | 11/06/2028 17:30 Sunday | Tailem Bend - South East No.1 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | SA Maintenance 6.4 Days |
| SA | ElectraNet | 12/06/2028 07:30 Monday | 18/06/2028 17:30 Sunday | Tailem Bend (6595) 275 kV Circuit Breaker | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | SA Maintenance 6.4 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? Generator Aware? | Inter-Regional | Impact Region, Reason and Duration |
|--------|------------|----------------------------|----------------------------|---|---|-----------------------------|-----------------------------|------------|---------------------------------|----------------|--|
| SA | ElectraNet | 19/06/2028 07:30 Monday | 25/06/2028 17:30 Sunday | Tailem Bend - Tungkillo No.1 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | SA Maintenance 6.4 Days |
| SA | ElectraNet | 26/06/2028 07:30 Monday | 02/07/2028 17:30 Sunday | Tailem Bend (6595) 275 kV Circuit Breaker | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | SA Maintenance 6.4 Days |
| SA | ElectraNet | 21/05/2029 07:30 Monday | 27/05/2029 19:30 Sunday | Heywood - South East No.1 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | ✓ | Maintenance 6.5 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? Generator Aware? | Inter-Regional | Impact Region, Reason and Duration |
|--------|------------|----------------------------|----------------------------|---|---|-----------------------------|-----------------------------|------------|---------------------------------|----------------|--|
| SA | ElectraNet | 28/05/2029 07:30 Monday | 03/06/2029 17:30 Sunday | Heywood - South East No.2 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | ✓ | Maintenance 6.4 Days |
| SA | ElectraNet | 04/06/2029 07:30 Monday | 10/06/2029 17:30 Sunday | Tailem Bend - South East No.1 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | Maintenance 6.4 Days |
| SA | ElectraNet | 11/06/2029 07:30 Monday | 17/06/2029 17:30 Sunday | Tailem Bend - South East No.2 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | SA Maintenance 6.4 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? Generator Aware? | Inter-Regional | Impact Region, Reason and Duration |
|--------|------------|----------------------------|----------------------------|---|---|-----------------------------|-----------------------------|------------|---------------------------------|----------------|--|
| SA | ElectraNet | 18/06/2029 07:30 Monday | 24/06/2029 17:30 Sunday | Tailem Bend - Tungkillo No.1 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | SA Maintenance 6.4 Days |
| SA | ElectraNet | 25/06/2029 07:30 Monday | 01/07/2029 17:30 Sunday | Tailem Bend (6595) 275 kV Circuit Breaker | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | Maintenance 6.4 Days |
| SA | ElectraNet | 20/05/2030 07:30 Monday | 26/05/2030 19:30 Sunday | Heywood - South East No.1 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | ✓ | VIC / SA Maintenance 6.5 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? Generator Aware? | Inter-Regional | Impact Region, Reason and Duration |
|--------|------------|----------------------------|----------------------------|---|---|-----------------------------|-----------------------------|------------|---------------------------------|----------------|--|
| SA | ElectraNet | 27/05/2030 07:30 Monday | 02/06/2030 17:30 Sunday | Heywood - South East No.2 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | ✓ | Maintenance 6.4 Days |
| SA | ElectraNet | 03/06/2030 07:30 Monday | 09/06/2030 17:30 Sunday | Tailem Bend - South East No.1 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | Maintenance 6.4 Days |
| SA | ElectraNet | 10/06/2030 07:30 Monday | 16/06/2030 17:30 Sunday | Tailem Bend - South East No.2 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | Maintenance 6.4 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? | Inter-Regional | Impact Region, Reason and Duration |
|--------|------------|----------------------------|----------------------------|---|---|-----------------------------|-----------------------------|------------|-------------|----------------|--|
| SA | ElectraNet | 17/06/2030 07:30 Monday | 23/06/2030 17:30 Sunday | Tailem Bend - Tungkillo No.1 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | Maintenance 6.4 Days |
| SA | ElectraNet | 24/06/2030 07:30 Monday | 30/06/2030 17:30 Sunday | Tailem Bend (6595) 275 kV Circuit Breaker | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs Night: 12 hrs | Planned - SUBMIT | | | | Maintenance 6.4 Days |

The following fields of data are submitted by NSPs to AEMO.

Disclaimer

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice, and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies. AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

[✓] **Unplanned** - Outage is forced outage, trip or submitted with short notice.

[✓] DNSP(s) Aware - The TNSP that submitted the outage confirms they have notified DNSP(s) that are impacted by this outage and made aware of the risks of next contingency.

[✓] Generator(s) Aware - The TNSP that submitted the outage confirms they have notified generator(s) that are directly impacted by this outage and made aware of potential risks of next credible contingency.

[✓] Inter-Regional - The TNSP that submitted the outage confirms they have notified other TNSP(s) that may be impacted by this outage, often in the neighbouring region.

^{*} make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and

^{*} are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.