

## Upcoming High-Impact Outages (HIOs) in the NEM - Information Current as of: 10 June 2025 - 0807 hrs -

## Newly Added Outage Update(s) since the last notification Withdrawn / UTP since the last notification

| Region | NSP       | Start                         | Finish                        | Network Asset                                  | Impact  | Recall                     | Status and<br>Market Notice | Unplanned? | DNSP Aware? | Generator Aware: | Impact Region,<br>Reason and<br>Duration |
|--------|-----------|-------------------------------|-------------------------------|--|---|----------------------------|-----------------------------|------------|-------------|------------------|--|
| QLD    | Powerlink | 09/06/2025 10:00<br>Monday    | 12/06/2025 17:00<br>Thursday  | Bouldercombe - Broadsound (820) 275 kV<br>Line | < <new last="" notification="" since="" the="">&gt; This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.</new>   | Day: 5 hrs<br>Night: 3 hrs | In Progress - PTP           |            | <b>✓</b>    |                  | QLD<br>Commissioning<br>3.3 Days         |
| VIC    | AusNet    | 10/06/2025 07:00<br>Tuesday   | 10/06/2025 17:00<br>Tuesday   | Moorabool–Sydenham No.2 500 kV Line            | < <this been="" has="" outage="" withdrawn!="">&gt; A credible contingency event during this planned outage may require market intervention through issuing of directions</this>  | Day: 4 hrs<br>Night: NA    | Withdrawn                   |            |             |                  | VIC<br>Maintenance<br>10 Hours           |
| VIC    | AusNet    | 11/06/2025 07:00<br>Wednesday | 11/06/2025 17:00<br>Wednesday | Red Cliffs-Wemen 220 kV Line                   | < <this been="" has="" outage="" withdrawn!="">&gt; A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.</this>  | Day: 2 hrs<br>Night: NA    | Withdrawn                   |            |             |                  | VIC<br>Maintenance<br>10 Hours           |
| QLD    | Powerlink | 16/06/2025 08:00<br>Monday    | 20/06/2025 17:00<br>Friday    | Bouldercombe - Broadsound (820) 275 kV<br>Line | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.  | Day: 5 hrs<br>Night: 3 hrs | Planned - MTLTP             |            |             |                  | QLD<br>Commissioning<br>4.4 Days         |
| VIC    | AusNet    | 17/06/2025 06:00<br>Tuesday   | 17/06/2025 18:00<br>Tuesday   | Moorabool-Cressy No.1 500kV Line               | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs<br>Night: NA    | Planned - MTLTP             |            |             | ✓ ✓              | VIC / SA<br>Maintenance<br>12 Hours      |
| VIC    | AusNet    | 18/06/2025 07:30<br>Wednesday | 18/06/2025 16:30<br>Wednesday | Hazelwood - Cranbourne 500 kV Line             | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).                                     | Day: 1 hr<br>Night: NA     | Planned - MTLTP             |            |             |                  | VIC<br>Maintenance<br>9 Hours            |

| Region | NSP       | Start                         | Finish                        | Network Asset                                  | Impact  | Recall                     | Status and<br>Market Notice | Unplanned? | DNSP Aware? | Inter-Reg | Impact Region,<br>Reason and<br>Duration |
|--------|-----------|-------------------------------|-------------------------------|--|---|----------------------------|-----------------------------|------------|-------------|-----------|--|
| VIC    | TOA       | 19/06/2025 07:00<br>Thursday  | 19/06/2025 12:00<br>Thursday  | Ararat - Waubra 220 kV Line                    | A credible contingency event during this planned outage may require:  Load shedding in the Victorian outer grid  Market intervention through issuing of directions.   | Day: 1.5 hrs<br>Night: NA  | Planned - MTLTP             |            | < ,         | / /       | VIC<br>Maintenance<br>5 Hours            |
| VIC    | AusNet    | 22/06/2025 07:00<br>Sunday    | 22/06/2025 16:30<br>Sunday    | Rowville - South Morang 500 kV Line            | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 0 mins<br>Night: NA   | Planned - MTLTP             |            |             |           | VIC<br>Maintenance<br>9.5 Hours          |
| QLD    | Powerlink | 23/06/2025 07:00<br>Monday    | 27/06/2025 17:00<br>Friday    | Bouldercombe - Broadsound (820) 275 kV<br>Line | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.  | Day: 5 hrs<br>Night: 3 hrs | Planned - SUBMIT            |            |             |           | QLD<br>Commissioning<br>4.4 Days         |
| VIC    | AusNet    | 24/06/2025 06:00<br>Tuesday   | 24/06/2025 18:00<br>Tuesday   | Kiamal SF-Red Cliffs 220 kV LINE               | A credible contingency event during this planned outage may require:  Load shedding in the Victorian outer grid  Market intervention through issuing of directions.   | Day: 4 hrs<br>Night: NA    | Planned - MTLTP             |            | ✓ ,         | / /       | VIC<br>Maintenance<br>12 Hours           |
| VIC    | AusNet    | 25/06/2025 06:00<br>Wednesday | 25/06/2025 18:00<br>Wednesday | Moorabool–Sydenham No.1 500 kV Line            | A credible contingency event during this planned outage may require market intervention through issuing of directions   | Day: 2 hrs<br>Night: NA    | Planned - MTLTP             |            |             |           | VIC<br>Maintenance<br>12 Hours           |
| VIC    | AusNet    | 25/06/2025 06:30<br>Wednesday | 25/06/2025 18:00<br>Wednesday | Red Cliffs-Wemen 220 kV Line                   | A credible contingency event during this planned outage may require:  Load shedding in the Victorian outer grid  Market intervention through issuing of directions.   | Day: 4 hrs<br>Night: NA    | Planned - MTLTP             |            | ✓ ,         | / /       | VIC<br>Maintenance<br>11.5 Hours         |
| VIC    | AusNet    | 25/06/2025 07:00<br>Wednesday | 25/06/2025 17:00<br>Wednesday | Moorabool–Sydenham No.1 500 kV Line            | < <this been="" has="" outage="" withdrawn!="">&gt; A credible contingency event during this planned outage may require market intervention through issuing of directions</this>  | Day: 4 hrs<br>Night: NA    | Withdrawn                   |            |             |           | VIC<br>Maintenance<br>10 Hours           |
| QLD    | Powerlink | 30/06/2025 07:00<br>Monday    | 04/07/2025 17:00<br>Friday    | Bouldercombe - Broadsound (820) 275 kV<br>Line | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.  | Day: 5 hrs<br>Night: 3 hrs | Planned - RESUBMIT          |            |             |           | QLD<br>Commissioning<br>4.4 Days         |

| Region | NSP        | Start                        | Finish                       | Network Asset                               | Impact  | Recall                      | Status and<br>Market Notice | Unplanned? | Generator Aware? | Inter-Regional | Impact Region,<br>Reason and<br>Duration |
|--------|------------|------------------------------|------------------------------|---|---|-----------------------------|-----------------------------|------------|------------------|----------------|--|
| SA     | ElectraNet | 30/06/2025 07:30<br>Monday   | 06/07/2025 17:30<br>Sunday   | Tailem Bend - South East No.1 275 kV Line   | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - MTLTP             |            |                  |                | SA<br>Maintenance<br>6.4 Days            |
| VIC    | AusNet     | 01/07/2025 07:00<br>Tuesday  | 01/07/2025 16:30<br>Tuesday  | South Morang - Sydenham No.1 500 kV<br>Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).                                 | Day: 2 hrs<br>Night: NA     | Planned - MTLTP             |            |                  |                | VIC<br>Commissioning<br>9.5 Hours        |
| VIC    | AusNet     | 03/07/2025 07:00<br>Thursday | 03/07/2025 16:30<br>Thursday | South Morang - Sydenham No.2 500 kV<br>Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).                                 | Day: 2 hrs<br>Night: NA     | Planned - MTLTP             |            |                  |                | VIC<br>Maintenance<br>9.5 Hours          |
| VIC    | AusNet     | 04/07/2025 06:00<br>Friday   | 04/07/2025 18:00<br>Friday   | Keilor – Sydenham 500 kV Line               | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria  • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).                                | Day: 2 hrs<br>Night: NA     | Planned - MTLTP             |            |                  |                | VIC<br>Maintenance<br>12 Hours           |
| SA     | ElectraNet | 07/07/2025 07:30<br>Monday   | 13/07/2025 17:30<br>Sunday   | Tailem Bend - South East No.2 275 kV Line   | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - MTLTP             |            |                  |                | SA<br>Maintenance<br>6.4 Days            |

| Region | NSP       | Start                        | Finish                       | Network Asset                        | Impact  | Recall                     | Status and<br>Market Notice | DNSP Aware? | Juter-Regional | Impact Region,<br>Reason and<br>Duration |
|--------|-----------|------------------------------|------------------------------|--------------------------------------|---|----------------------------|-----------------------------|-------------|----------------|--|
| QLD    | Powerlink | 08/07/2025 07:00<br>Tuesday  | 11/07/2025 17:00<br>Friday   | Strathmore - Ross (8857) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.  | Day: 6 hrs<br>Night: 8 hrs | Planned - SUBMIT            | ✓           |                | QLD<br>Commissioning<br>3.4 Days         |
| VIC    | AusNet    | 11/07/2025 06:00<br>Friday   | 11/07/2025 18:00<br>Friday   | Cressy - Mortlake No. 2 500kV line   | < <new last="" notification="" since="" the="">&gt; A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new>  | Day: 2 hrs<br>Night: NA    | Planned - MTLTP             |             | / /            | VIC / SA<br>Maintenance<br>12 Hours      |
| VIC    | AusNet    | 11/07/2025 07:00<br>Friday   | 11/07/2025 17:00<br>Friday   | Cressy - Mortlake No.2 500kV line    | < <this been="" has="" outage="" withdrawn!="">&gt; A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</this> | Day: 30 mins<br>Night: NA  | Withdrawn                   |             |                | VIC / SA<br>Maintenance<br>10 Hours      |
| VIC    | AusNet    | 12/07/2025 06:00<br>Saturday | 12/07/2025 18:00<br>Saturday | Cressy - Mortlake No.2 500kV line    | < <new last="" notification="" since="" the="">&gt; A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new>  | Day: 2 hrs<br>Night: NA    | Planned - MTLTP             | ,           | / /            | VIC / SA<br>Maintenance<br>12 Hours      |

| Region | NSP        | Start                         | Finish                        | Network Asset                                  | Impact  | Recall                      | Status and<br>Market Notice | Unplanned? | Generator Aware? | Inter-Regional | Impact Region,<br>Reason and<br>Duration |
|--------|------------|-------------------------------|-------------------------------|--|---|-----------------------------|-----------------------------|------------|------------------|----------------|--|
| VIC    | AusNet     | 12/07/2025 07:00<br>Saturday  | 12/07/2025 17:00<br>Saturday  | Cressy - Mortlake No.2 500kV line              | < <this been="" has="" outage="" withdrawn!="">&gt; A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</this> | Day: 30 mins<br>Night: NA   | Withdrawn                   |            |                  |                | VIC / SA<br>Maintenance<br>10 Hours      |
| QLD    | Powerlink  | 14/07/2025 07:00<br>Monday    | 18/07/2025 17:00<br>Friday    | Bouldercombe - Broadsound (820) 275 kV<br>Line | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.  | Day: 5 hrs<br>Night: 3 hrs  | Planned - SUBMIT            |            |                  |                | QLD<br>Commissioning<br>4.4 Days         |
| SA     | ElectraNet | 14/07/2025 07:30<br>Monday    | 15/07/2025 17:30<br>Tuesday   | Heywood - South East No.1 275 kV Line          | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event.   | Day: 6 hrs<br>Night: 12 hrs | Planned - MTLTP             |            |                  | <b>✓</b>       | VIC / SA<br>Maintenance<br>1.4 Days      |
| VIC    | AusNet     | 15/07/2025 07:00<br>Tuesday   | 15/07/2025 17:00<br>Tuesday   | Keilor – Sydenham 500 kV Line                  | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).   | Day: 5 hrs<br>Night: NA     | Planned - MTLTP             |            |                  |                | VIC<br>Maintenance<br>10 Hours           |
| VIC    | AusNet     | 16/07/2025 07:00<br>Wednesday | 16/07/2025 17:00<br>Wednesday | Kiamal SF - MurraWarra 220 kV Line             | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.   | Day: 1 hr<br>Night: NA      | Planned - MTLTP             | ~          | ′ ✓              | <b>✓</b>       | VIC<br>Maintenance<br>10 Hours           |
| VIC    | AusNet     | 17/07/2025 07:00<br>Thursday  | 17/07/2025 17:00<br>Thursday  | Kiamal SF - MurraWarra 220 kV Line             | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.   | Day: 1 hr<br>Night: NA      | Planned - MTLTP             | ~          | <i>'</i>         | <b>✓</b>       | VIC<br>Maintenance<br>10 Hours           |

| Region | NSP        | Start                        | Finish                        | Network Asset                            | Impact  | Recall                      | Status and<br>Market Notice | Unplanned? | Generator Aware? | Inter-Regional | Impact Region,<br>Reason and<br>Duration |
|--------|------------|------------------------------|-------------------------------|--|---|-----------------------------|-----------------------------|------------|------------------|----------------|--|
| VIC    | AusNet     | 18/07/2025 07:00<br>Friday   | 18/07/2025 17:30<br>Friday    | Bulgana - Horsham 220 kV Line            | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.  | Day: 30 mins<br>Night: NA   | Planned - MTLTP             |            |                  |                | VIC<br>Maintenance<br>10.5 Hours         |
| VIC    | AusNet     | 19/07/2025 07:00<br>Saturday | 19/07/2025 17:30<br>Saturday  | Bulgana - Horsham 220 kV Line            | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.   | Day: 30 mins<br>Night: NA   | Planned - MTLTP             |            |                  |                | VIC<br>Maintenance<br>10.5 Hours         |
| SA     | ElectraNet | 21/07/2025 07:30<br>Monday   | 23/07/2025 17:30<br>Wednesday | Heywood - South East No.2 275 kV Line    | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - RESUBMIT          |            |                  | <b>✓</b>       | VIC / SA<br>Maintenance<br>2.4 Days      |
| VIC    | AusNet     | 27/07/2025 07:00<br>Sunday   | 27/07/2025 17:00<br>Sunday    | Rowville - South Morang 500 kV Line      | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).                                     | Day: 2 hrs<br>Night: NA     | Planned - MTLTP             |            |                  |                | VIC<br>Maintenance<br>10 Hours           |
| VIC    | AusNet     | 28/07/2025 07:00<br>Monday   | 28/07/2025 17:00<br>Monday    | Rowville - South Morang 500 kV Line      | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).                                     | Day: 2 hrs<br>Night: NA     | Planned - SUBMIT            |            |                  |                | VIC<br>Maintenance<br>10 Hours           |
| SA     | ElectraNet | 28/07/2025 07:30<br>Monday   | 03/08/2025 17:30<br>Sunday    | Tailem Bend - Tungkillo No.1 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  |                | SA<br>Maintenance<br>6.4 Days            |

| Region | NSP        | Start                         | Finish                        | Network Asset                            | Impact  | Recall                       | Status and<br>Market Notice |   | DNSP Aware: | Inter-Regional | Impact Region,<br>Reason and<br>Duration |
|--------|------------|-------------------------------|-------------------------------|--|---|------------------------------|-----------------------------|---|-------------|----------------|--|
| SA     | ElectraNet | 04/08/2025 07:30<br>Monday    | 10/08/2025 17:30<br>Sunday    | Tailem Bend - Tungkillo No.2 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs  | Planned - SUBMIT            |   |             |                | SA<br>Maintenance<br>6.4 Days            |
| VIC    | AusNet     | 06/08/2025 06:00<br>Wednesday | 06/08/2025 19:30<br>Wednesday | Kiamal SF-Red Cliffs 220 kV LINE         | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.   | Day: 2 hrs<br>Night: NA      | Planned - SUBMIT            |   |             |                | VIC<br>Maintenance<br>13.5 Hours         |
| NSW    | Transgrid  | 13/08/2025 07:30<br>Wednesday | 13/08/2025 16:00<br>Wednesday | Armidale - Tamworth (86) 330 kV Line     | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM  | Day: 2 hrs<br>Night: NA      | Planned - SUBMIT            | , | / /         | · /            | NSW / QLD<br>Maintenance<br>8.5 Hours    |
| NSW    | Transgrid  | 14/08/2025 07:30<br>Thursday  | 14/08/2025 16:00<br>Thursday  | Armidale - Tamworth (86) 330 kV Line     | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM  | Day: 2 hrs<br>Night: NA      | Planned - SUBMIT            | , | / /         | <b>/</b>       | NSW / QLD<br>Maintenance<br>8.5 Hours    |
| NSW    | Transgrid  | 15/08/2025 07:30<br>Friday    | 15/08/2025 16:00<br>Friday    | Armidale - Tamworth (86) 330 kV Line     | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM  | Day: 2 hrs<br>Night: NA      | Planned - SUBMIT            | , | / /         | <i>'</i>       | NSW / QLD<br>Maintenance<br>8.5 Hours    |
| VIC    | AusNet     | 19/08/2025 07:00<br>Tuesday   | 19/08/2025 17:00<br>Tuesday   | Kiamal SF-Red Cliffs 220 kV LINE         | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.   | Day: 2 hrs<br>Night: NA      | Planned - SUBMIT            |   |             |                | VIC<br>Maintenance<br>10 Hours           |
| QLD    | Powerlink  | 19/08/2025 08:00<br>Tuesday   | 24/11/2025 07:59<br>Monday    | Nebo - Strathmore (822) 275 kV Line      | < <this been="" has="" outage="" withdrawn!="">&gt; This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.</this>  | Day: 0 mins<br>Night: NA     | Withdrawn                   |   |             |                | QLD<br>Maintenance<br>97 Days            |
| VIC    | AusNet     | 20/08/2025 07:00<br>Wednesday | 20/08/2025 17:00<br>Wednesday | Red Cliffs-Wemen 220 kV Line             | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.   | Day: 2 hrs<br>Night: NA      | Planned - SUBMIT            |   |             |                | VIC<br>Maintenance<br>10 Hours           |
| NSW    | Transgrid  | 02/09/2025 07:00<br>Tuesday   | 13/09/2025 17:00<br>Saturday  | Dumaresq-Sapphire (8J) 330kV LINE        | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM  | Day: 12 hrs<br>Night: 12 hrs | Planned - SUBMIT            |   | ~           | \ \ \ \        | NSW/QLD<br>Commissioning<br>11.4 Days    |

| Region | NSP       | Start                         | Finish                        | Network Asset  | Impact   | Recall                       | Status and<br>Market Notice | Unplanned?<br>DNSP Aware? | Generator Aware? | Inter-Regional | Impact Region,<br>Reason and<br>Duration |
|--------|-----------|-------------------------------|-------------------------------|--|--|------------------------------|-----------------------------|---------------------------|------------------|----------------|--|
| VIC    | AusNet    | 03/09/2025 05:30<br>Wednesday | 03/09/2025 15:00<br>Wednesday | Hazelwood - Loy Yang Power Station No.1<br>500 kV Line | A credible contingency event during this planned outage could cause:  • A large reduction in generation in Victoria  • Load shedding in Victoria   | Day: 0 mins<br>Night: NA     | Planned - RESUBMIT          |                           |                  |                | VIC<br>Maintenance<br>9.5 Hours          |
| VIC    | AusNet    | 04/09/2025 06:00<br>Thursday  | 04/09/2025 17:00<br>Thursday  | Heywood - South East No.2 275 kV Line                  | < <new last="" notification="" since="" the="">&gt; A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 2 hrs<br>Night: NA      | Planned - SUBMIT            |                           |                  |                | VIC / SA<br>Maintenance<br>11 Hours      |
| VIC    | AusNet    | 08/09/2025 06:00<br>Monday    | 08/09/2025 17:00<br>Monday    | Heywood - South East No.2 275 kV Line                  | < <new last="" notification="" since="" the="">&gt; A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 2 hrs<br>Night: NA      | Planned - SUBMIT            |                           |                  |                | VIC / SA<br>Maintenance<br>11 Hours      |
| NSW    | Transgrid | 15/09/2025 07:00<br>Monday    | 20/09/2025 17:00<br>Saturday  | Dumaresq-Sapphire (8J) 330kV LINE                      | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM   | Day: 12 hrs<br>Night: 12 hrs | Planned - SUBMIT            |                           | <b>✓</b>         | <b>✓</b>       | NSW/QLD<br>Commissioning<br>5.4 Days     |
| VIC    | AusNet    | 18/09/2025 06:00<br>Thursday  | 18/09/2025 17:00<br>Thursday  | Heywood - South East No.2 275 kV Line                  | < <new last="" notification="" since="" the="">&gt; A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 2 hrs<br>Night: NA      | Planned - SUBMIT            |                           |                  |                | VIC / SA<br>Maintenance<br>11 Hours      |

| Region | NSP       | Start                         | Finish                        | Network Asset                         | Impact   | Recall                     | Status and<br>Market Notice | Unplanned? | Generator Aware? | Inter-Regional | Impact Region,<br>Reason and<br>Duration |
|--------|-----------|-------------------------------|-------------------------------|---------------------------------------|--|----------------------------|-----------------------------|------------|------------------|----------------|--|
| VIC    | AusNet    | 22/09/2025 06:00<br>Monday    | 22/09/2025 17:00<br>Monday    | Heywood - South East No.2 275 kV Line | < <new last="" notification="" since="" the="">&gt; A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 2 hrs<br>Night: NA    | Planned - SUBMIT            |            |                  |                | VIC / SA<br>Maintenance<br>11 Hours      |
| NSW    | Transgrid | 22/09/2025 08:00<br>Monday    | 22/09/2025 17:00<br>Monday    | Buronga - Red Cliffs (X9) 220 kV line | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.  | Day: 8 hrs<br>Night: NA    | Planned - SUBMIT            |            | <b>✓</b>         | <b>✓</b>       | NSW / VIC<br>Commissioning<br>9 Hours    |
| NSW    | Transgrid | 22/09/2025 08:00<br>Monday    | 07/10/2025 16:00<br>Tuesday   | Buronga - Red Cliffs (X1) 220 kV line | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.  | Day: 8 hrs<br>Night: 4 hrs | Planned - SUBMIT            |            | <b>✓</b>         | <b>✓</b>       | NSW / VIC<br>Commissioning<br>15.3 Days  |
| NSW    | Transgrid | 23/09/2025 08:00<br>Tuesday   | 23/09/2025 17:00<br>Tuesday   | Buronga - Red Cliffs (X9) 220 kV line | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.  | Day: 8 hrs<br>Night: NA    | Planned - SUBMIT            |            | <b>✓</b>         | <b>✓</b>       | NSW / VIC<br>Commissioning<br>9 Hours    |
| NSW    | Transgrid | 24/09/2025 08:00<br>Wednesday | 24/09/2025 17:00<br>Wednesday | Buronga - Red Cliffs (X9) 220 kV line | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.  | Day: 8 hrs<br>Night: NA    | Planned - SUBMIT            |            | <b>✓</b>         | <b>✓</b>       | NSW / VIC<br>Commissioning<br>9 Hours    |
| NSW    | Transgrid | 25/09/2025 08:00<br>Thursday  | 25/09/2025 17:00<br>Thursday  | Buronga - Red Cliffs (X9) 220 kV line | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.  | Day: 8 hrs<br>Night: NA    | Planned - SUBMIT            | v          | / /              |                | NSW / VIC<br>Commissioning<br>9 Hours    |
| NSW    | Transgrid | 26/09/2025 08:00<br>Friday    | 26/09/2025 17:00<br>Friday    | Buronga - Red Cliffs (X9) 220 kV line | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.  | Day: 8 hrs<br>Night: NA    | Planned - SUBMIT            | v          | <b>/ /</b>       |                | NSW / VIC<br>Commissioning<br>9 Hours    |
| QLD    | Powerlink | 27/09/2025 07:00<br>Saturday  | 27/09/2025 16:00<br>Saturday  | Nebo - Broadsound (8846) 275 kV Line  | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.   | Day: 2 hrs<br>Night: NA    | Planned - SUBMIT            |            |                  |                | QLD<br>Maintenance<br>9 Hours            |
| NSW    | Transgrid | 27/09/2025 08:00<br>Saturday  | 27/09/2025 17:00<br>Saturday  | Buronga - Red Cliffs (X9) 220 kV line | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.  | Day: 8 hrs<br>Night: NA    | Planned - SUBMIT            |            | ~                | ✓              | NSW / VIC<br>Commissioning<br>9 Hours    |

| Region | NSP       | Start                         | Finish                        | Network Asset                               | Impact   | Recall                     | Status and<br>Market Notice | Unplanned? | Generator Aware? | Inter-Regional | Impact Region,<br>Reason and<br>Duration |
|--------|-----------|-------------------------------|-------------------------------|---|--|----------------------------|-----------------------------|------------|------------------|----------------|--|
| NSW    | Transgrid | 28/09/2025 08:00<br>Sunday    | 28/09/2025 17:00<br>Sunday    | Buronga - Red Cliffs (X9) 220 kV line       | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.  | Day: 8 hrs<br>Night: NA    | Planned - SUBMIT            |            | ~                | · 🗸            | NSW / VIC<br>Commissioning<br>9 Hours    |
| NSW    | Transgrid | 29/09/2025 08:00<br>Monday    | 29/09/2025 17:00<br>Monday    | Buronga - Red Cliffs (X9) 220 kV line       | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.  | Day: 8 hrs<br>Night: NA    | Planned - SUBMIT            |            |                  |                | NSW / VIC<br>Commissioning<br>9 Hours    |
| NSW    | Transgrid | 30/09/2025 07:00<br>Tuesday   | 11/10/2025 16:00<br>Saturday  | Armidale - Dumaresq (8C) 330 kV Line        | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM   | Day: 6 hrs<br>Night: 6 hrs | Planned - SUBMIT            |            |                  |                | NSW / QLD<br>Commissioning<br>11.4 Days  |
| NSW    | Transgrid | 30/09/2025 08:00<br>Tuesday   | 30/09/2025 17:00<br>Tuesday   | Buronga - Red Cliffs (X9) 220 kV line       | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.  | Day: 8 hrs<br>Night: NA    | Planned - SUBMIT            |            |                  |                | NSW / VIC<br>Commissioning<br>9 Hours    |
| NSW    | Transgrid | 01/10/2025 08:00<br>Wednesday | 01/10/2025 17:00<br>Wednesday | Buronga - Red Cliffs (X9) 220 kV line       | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.  | Day: 8 hrs<br>Night: NA    | Planned - SUBMIT            |            |                  |                | NSW / VIC<br>Commissioning<br>9 Hours    |
| VIC    | AusNet    | 02/10/2025 06:00<br>Thursday  | 02/10/2025 17:00<br>Thursday  | South Morang - Sydenham No.2 500 kV<br>Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).  | Day: NA<br>Night: NA       | Planned - SUBMIT            |            |                  |                | VIC<br>Maintenance<br>11 Hours           |
| VIC    | AusNet    | 02/10/2025 06:00<br>Thursday  | 02/10/2025 17:00<br>Thursday  | Heywood - South East No.2 275 kV Line       | < <new last="" notification="" since="" the="">&gt; A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 2 hrs<br>Night: NA    | Planned - SUBMIT            |            |                  |                | VIC / SA<br>Maintenance<br>11 Hours      |

| Region | NSP       | Start                        | Finish                       | Network Asset                               | Impact   | Recall                    | Status and<br>Market Notice | Unplanned? | Generator Aware? | Inter-Regional | Impact Region,<br>Reason and<br>Duration |
|--------|-----------|------------------------------|------------------------------|---|--|---------------------------|-----------------------------|------------|------------------|----------------|--|
| VIC    | AusNet    | 02/10/2025 06:00<br>Thursday | 02/10/2025 17:00<br>Thursday | Heywood - South East No.2 275 kV Line       | < <new last="" notification="" since="" the="">&gt; A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 2 hrs<br>Night: NA   | Planned - SUBMIT            |            |                  |                | VIC / SA<br>Maintenance<br>11 Hours      |
| VIC    | AusNet    | 02/10/2025 07:00<br>Thursday | 07/10/2025 17:00<br>Tuesday  | South Morang - Sydenham No.2 500 kV<br>Line | < <new last="" notification="" since="" the="">&gt; This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).</new>                                  | Day: 120 hrs<br>Night: NA | Planned - SUBMIT            |            |                  |                | VIC<br>Maintenance<br>5.4 Days           |
| NSW    | Transgrid | 02/10/2025 08:00<br>Thursday | 02/10/2025 17:00<br>Thursday | Buronga - Red Cliffs (X9) 220 kV line       | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.  | Day: 8 hrs<br>Night: NA   | Planned - SUBMIT            |            |                  |                | NSW / VIC<br>Commissioning<br>9 Hours    |
| VIC    | AusNet    | 03/10/2025 06:00<br>Friday   | 03/10/2025 17:00<br>Friday   | South Morang - Sydenham No.2 500 kV<br>Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria  • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).   | Day: NA<br>Night: NA      | Planned - SUBMIT            |            |                  |                | VIC<br>Maintenance<br>11 Hours           |
| NSW    | Transgrid | 03/10/2025 08:00<br>Friday   | 03/10/2025 17:00<br>Friday   | Buronga - Red Cliffs (X9) 220 kV line       | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.  | Day: 8 hrs<br>Night: NA   | Planned - SUBMIT            |            |                  |                | NSW / VIC<br>Commissioning<br>9 Hours    |
| VIC    | AusNet    | 04/10/2025 06:00<br>Saturday | 04/10/2025 17:00<br>Saturday | South Morang - Sydenham No.2 500 kV<br>Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).  | Day: NA<br>Night: NA      | Planned - SUBMIT            |            |                  |                | VIC<br>Maintenance<br>11 Hours           |

| Region | NSP       | Start                        | Finish                        | Network Asset                               | Impact  | Recall                   | Status and<br>Market Notice | Unplanned? | Generator Aware? | Inter-Regional | Impact Region,<br>Reason and<br>Duration |
|--------|-----------|------------------------------|-------------------------------|---|---|--------------------------|-----------------------------|------------|------------------|----------------|--|
| NSW    | Transgrid | 04/10/2025 08:00<br>Saturday | 04/10/2025 17:00<br>Saturday  | Buronga - Red Cliffs (X9) 220 kV line       | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.   | Day: 8 hrs<br>Night: NA  | Planned - SUBMIT            |            |                  |                | NSW / VIC<br>Commissioning<br>9 Hours    |
| VIC    | AusNet    | 05/10/2025 06:00<br>Sunday   | 05/10/2025 17:00<br>Sunday    | South Morang - Sydenham No.2 500 kV<br>Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).   | Day: NA<br>Night: NA     | Planned - SUBMIT            |            |                  |                | VIC<br>Maintenance<br>11 Hours           |
| NSW    | Transgrid | 05/10/2025 07:00<br>Sunday   | 05/10/2025 16:00<br>Sunday    | Buronga - Red Cliffs (X9) 220 kV line       | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.   | Day: 8 hrs<br>Night: NA  | Planned - SUBMIT            |            |                  |                | NSW / VIC<br>Commissioning<br>9 Hours    |
| VIC    | AusNet    | 06/10/2025 06:00<br>Monday   | 06/10/2025 17:00<br>Monday    | South Morang - Sydenham No.2 500 kV<br>Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).   | Day: NA<br>Night: NA     | Planned - SUBMIT            |            |                  |                | VIC<br>Maintenance<br>11 Hours           |
| VIC    | AusNet    | 06/10/2025 06:00<br>Monday   | 08/10/2025 17:00<br>Wednesday | South Morang - Sydenham No.1 500 kV<br>Line | < <new last="" notification="" since="" the="">&gt; This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 60 hrs<br>Night: NA | Planned - SUBMIT            |            |                  |                | VIC<br>Maintenance<br>2.5 Days           |
| VIC    | AusNet    | 06/10/2025 07:00<br>Monday   | 06/10/2025 17:00<br>Monday    | South Morang - Sydenham No.1 500 kV<br>Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).   | Day: 24 hrs<br>Night: NA | Planned - SUBMIT            |            |                  |                | VIC<br>Maintenance<br>10 Hours           |
| NSW    | Transgrid | 06/10/2025 07:00<br>Monday   | 06/10/2025 16:00<br>Monday    | Buronga - Red Cliffs (X9) 220 kV line       | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.   | Day: 8 hrs<br>Night: NA  | Planned - SUBMIT            |            |                  |                | NSW / VIC<br>Commissioning<br>9 Hours    |

| Region | NSP       | Start                         | Finish                        | Network Asset                               | Impact   | Recall                   | Status and<br>Market Notice | Unplanned? | Generator Aware? | Inter-Regional | Impact Region,<br>Reason and<br>Duration |
|--------|-----------|-------------------------------|-------------------------------|---|--|--------------------------|-----------------------------|------------|------------------|----------------|--|
| VIC    | AusNet    | 07/10/2025 06:00<br>Tuesday   | 07/10/2025 17:00<br>Tuesday   | South Morang - Sydenham No.2 500 kV<br>Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria  • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).   | Day: NA<br>Night: NA     | Planned - SUBMIT            |            |                  |                | VIC<br>Maintenance<br>11 Hours           |
| VIC    | AusNet    | 07/10/2025 07:00<br>Tuesday   | 07/10/2025 17:00<br>Tuesday   | South Morang - Sydenham No.1 500 kV<br>Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria  • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).   | Day: 24 hrs<br>Night: NA | Planned - SUBMIT            |            |                  |                | VIC<br>Maintenance<br>10 Hours           |
| NSW    | Transgrid | 07/10/2025 07:00<br>Tuesday   | 07/10/2025 16:00<br>Tuesday   | Buronga - Red Cliffs (X9) 220 kV line       | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.  | Day: 8 hrs<br>Night: NA  | Planned - SUBMIT            |            |                  |                | NSW / VIC<br>Commissioning<br>9 Hours    |
| VIC    | AusNet    | 08/10/2025 07:00<br>Wednesday | 08/10/2025 17:00<br>Wednesday | South Morang - Sydenham No.1 500 kV<br>Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria  • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).   | Day: 24 hrs<br>Night: NA | Planned - SUBMIT            |            |                  |                | VIC<br>Maintenance<br>10 Hours           |
| VIC    | AusNet    | 10/10/2025 05:00<br>Friday    | 10/10/2025 16:00<br>Friday    | Heywood - South East No.2 275 kV Line       | < <new last="" notification="" since="" the="">&gt; A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 2 hrs<br>Night: NA  | Planned - SUBMIT            |            |                  |                | VIC / SA<br>Maintenance<br>11 Hours      |

| Region | NSP       | Start                         | Finish                        | Network Asset                               | Impact  | Recall                     | Status and<br>Market Notice | Unplanned? | Inter-Regional | Impact Region,<br>Reason and<br>Duration |
|--------|-----------|-------------------------------|-------------------------------|---|---|----------------------------|-----------------------------|------------|----------------|--|
| VIC    | AusNet    | 10/10/2025 06:00<br>Friday    | 15/10/2025 17:00<br>Wednesday | South Morang - Sydenham No.1 500 kV<br>Line | < <new last="" notification="" since="" the="">&gt; This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 120 hrs<br>Night: NA  | Planned - SUBMIT            |            |                | VIC<br>Maintenance<br>5.5 Days           |
| VIC    | AusNet    | 11/10/2025 06:30<br>Saturday  | 11/10/2025 16:00<br>Saturday  | Hazelwood - Cranbourne 500 kV Line          | < <new last="" notification="" since="" the="">&gt; This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 2 hrs<br>Night: NA    | Planned - SUBMIT            |            |                | VIC<br>Maintenance<br>9.5 Hours          |
| NSW    | Transgrid | 13/10/2025 06:00<br>Monday    | 18/10/2025 16:00<br>Saturday  | Armidale - Dumaresq (8C) 330 kV Line        | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM  | Day: 6 hrs<br>Night: 6 hrs | Planned - SUBMIT            |            |                | NSW / QLD<br>Commissioning<br>5.4 Days   |
| VIC    | AusNet    | 20/10/2025 06:00<br>Monday    | 20/10/2025 16:00<br>Monday    | Ballarat - Waubra 220 kV Line               | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.   | Day: 2 hrs<br>Night: NA    | Planned - SUBMIT            |            |                | VIC<br>Maintenance<br>10 Hours           |
| QLD    | Powerlink | 21/10/2025 07:00<br>Tuesday   | 21/10/2025 17:00<br>Tuesday   | Strathmore - Ross (8858) 275 kV Line        | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.  | Day: 30 mins<br>Night: NA  | Planned - SUBMIT            |            |                | QLD<br>Commissioning<br>10 Hours         |
| QLD    | Powerlink | 21/10/2025 07:00<br>Tuesday   | 21/10/2025 17:00<br>Tuesday   | Strathmore - Ross (8857) 275 kV Line        | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.  | Day: 30 mins<br>Night: NA  | Planned - SUBMIT            |            |                | QLD<br>Commissioning<br>10 Hours         |
| QLD    | Powerlink | 22/10/2025 07:00<br>Wednesday | 22/10/2025 17:00<br>Wednesday | Strathmore - Ross (8858) 275 kV Line        | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.  | Day: 30 mins<br>Night: NA  | Planned - SUBMIT            |            |                | QLD<br>Commissioning<br>10 Hours         |
| QLD    | Powerlink | 22/10/2025 07:00<br>Wednesday | 22/10/2025 17:00<br>Wednesday | Strathmore - Ross (8857) 275 kV Line        | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.  | Day: 30 mins<br>Night: NA  | Planned - SUBMIT            |            |                | QLD<br>Commissioning<br>10 Hours         |

| Region | NSP       | Start                         | Finish                        | Network Asset                        | Impact   | Recall                    | Status and<br>Market Notice | Unplanned? |          | Generator Aware? | Impact Region,<br>Reason and<br>Duration |
|--------|-----------|-------------------------------|-------------------------------|--------------------------------------|--|---------------------------|-----------------------------|------------|----------|------------------|--|
| VIC    | AusNet    | 22/10/2025 07:00<br>Wednesday | 22/10/2025 18:00<br>Wednesday | Dederang - Wodonga 330 kV Line       | This line outage offloads Darlington Point - Wagga 63 330kV line.  Possible load shedding and risk of large reduction in generation in NSW and interconnector capacity between NSW - Victoria following a credible contingency | Day: 4 hrs<br>Night: NA   | Planned - SUBMIT            |            | <b>✓</b> | <b>/</b>         | VIC<br>Maintenance<br>11 Hours           |
| QLD    | Powerlink | 23/10/2025 07:00<br>Thursday  | 23/10/2025 17:00<br>Thursday  | Strathmore - Ross (8858) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.                       | Day: 30 mins<br>Night: NA | Planned - SUBMIT            |            |          |                  | QLD<br>Commissioning<br>10 Hours         |
| QLD    | Powerlink | 23/10/2025 07:00<br>Thursday  | 23/10/2025 17:00<br>Thursday  | Strathmore - Ross (8857) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.                       | Day: 30 mins<br>Night: NA | Planned - SUBMIT            |            |          |                  | QLD<br>Commissioning<br>10 Hours         |
| VIC    | AusNet    | 23/10/2025 07:00<br>Thursday  | 23/10/2025 18:00<br>Thursday  | Dederang - Wodonga 330 kV Line       | This line outage offloads Darlington Point - Wagga 63 330kV line.  Possible load shedding and risk of large reduction in generation in NSW and interconnector capacity between NSW - Victoria following a credible contingency | Day: 4 hrs<br>Night: NA   | Planned - SUBMIT            |            | ✓        | ✓ .              | VIC<br>Maintenance<br>11 Hours           |
| VIC    | AusNet    | 24/10/2025 07:00<br>Friday    | 24/10/2025 15:00<br>Friday    | Ballarat - Waubra 220 kV Line        | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.  | Day: 60 hrs<br>Night: NA  | Planned - SUBMIT            |            |          |                  | VIC<br>Maintenance<br>8 Hours            |
| QLD    | Powerlink | 24/10/2025 07:00<br>Friday    | 24/10/2025 17:00<br>Friday    | Strathmore - Ross (8858) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.                       | Day: 30 mins<br>Night: NA | Planned - SUBMIT            |            |          |                  | QLD<br>Commissioning<br>10 Hours         |
| QLD    | Powerlink | 24/10/2025 07:00<br>Friday    | 24/10/2025 17:00<br>Friday    | Strathmore - Ross (8857) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.                       | Day: 30 mins<br>Night: NA | Planned - SUBMIT            |            |          |                  | QLD<br>Commissioning<br>10 Hours         |
| QLD    | Powerlink | 25/10/2025 07:00<br>Saturday  | 25/10/2025 17:00<br>Saturday  | Strathmore - Ross (8858) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.                       | Day: 30 mins<br>Night: NA | Planned - SUBMIT            |            |          |                  | QLD<br>Commissioning<br>10 Hours         |
| QLD    | Powerlink | 25/10/2025 07:00<br>Saturday  | 25/10/2025 17:00<br>Saturday  | Strathmore - Ross (8857) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.                       | Day: 30 mins<br>Night: NA | Planned - SUBMIT            |            |          |                  | QLD<br>Commissioning<br>10 Hours         |

| Region | NSP       | Start                       | Finish                       | Network Asset                               | Impact  | Recall                     | Status and<br>Market Notice | DNSP Aware?<br>Generator Aware? | Inter-Regional | Impact Region,<br>Reason and<br>Duration |
|--------|-----------|-----------------------------|------------------------------|---|---|----------------------------|-----------------------------|---------------------------------|----------------|--|
| QLD    | Powerlink | 26/10/2025 07:00<br>Sunday  | 26/10/2025 17:00<br>Sunday   | Strathmore - Ross (8858) 275 kV Line        | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.  | Day: 30 mins<br>Night: NA  | Planned - SUBMIT            |                                 |                | QLD<br>Commissioning<br>10 Hours         |
| QLD    | Powerlink | 26/10/2025 07:00<br>Sunday  | 26/10/2025 17:00<br>Sunday   | Strathmore - Ross (8857) 275 kV Line        | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.  | Day: 30 mins<br>Night: NA  | Planned - SUBMIT            |                                 |                | QLD<br>Commissioning<br>10 Hours         |
| QLD    | Powerlink | 27/10/2025 07:00<br>Monday  | 27/10/2025 17:00<br>Monday   | Strathmore - Ross (8858) 275 kV Line        | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.  | Day: 30 mins<br>Night: NA  | Planned - SUBMIT            |                                 |                | QLD<br>Commissioning<br>10 Hours         |
| QLD    | Powerlink | 27/10/2025 07:00<br>Monday  | 27/10/2025 17:00<br>Monday   | Strathmore - Ross (8857) 275 kV Line        | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.  | Day: 30 mins<br>Night: NA  | Planned - SUBMIT            |                                 |                | QLD<br>Commissioning<br>10 Hours         |
| NSW    | Transgrid | 28/10/2025 06:00<br>Tuesday | 08/11/2025 16:00<br>Saturday | Armidale - Dumaresq (8C) 330 kV Line        | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM  | Day: 6 hrs<br>Night: 6 hrs | Planned - SUBMIT            |                                 |                | NSW / QLD<br>Commissioning<br>11.4 Days  |
| VIC    | AusNet    | 28/10/2025 06:00<br>Tuesday | 28/10/2025 17:00<br>Tuesday  | South Morang - Sydenham No.2 500 kV<br>Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).   | Day: NA<br>Night: NA       | Planned - SUBMIT            |                                 |                | VIC<br>Maintenance<br>11 Hours           |
| VIC    | AusNet    | 28/10/2025 06:00<br>Tuesday | 30/10/2025 17:00<br>Thursday | South Morang - Sydenham No.2 500 kV<br>Line | < <new last="" notification="" since="" the="">&gt; This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 60 hrs<br>Night: NA   | Planned - SUBMIT            |                                 |                | VIC<br>Maintenance<br>2.5 Days           |

| Region | NSP        | Start                         | Finish                        | Network Asset                               | Impact  | Recall                       | Status and<br>Market Notice | Unplanned? | DNSP Aware? | Inter-Regional | Impact Region,<br>Reason and<br>Duration |
|--------|------------|-------------------------------|-------------------------------|---|---|------------------------------|-----------------------------|------------|-------------|----------------|--|
| QLD    | Powerlink  | 28/10/2025 08:00<br>Tuesday   | 28/10/2025 16:00<br>Tuesday   | Nebo - Strathmore (8845) 275 kV Line        | < <this been="" has="" outage="" withdrawn!="">&gt; This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.</this>  | Day: 2 hrs<br>Night: 2 hrs   | Withdrawn                   |            |             |                | QLD<br>Maintenance<br>8 Hours            |
| QLD    | Powerlink  | 28/10/2025 08:00<br>Tuesday   | 28/10/2025 16:00<br>Tuesday   | Nebo - Strathmore (8845) 275 kV Line        | < <new last="" notification="" since="" the="">&gt; This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.</new>   | Day: 2 hrs<br>Night: 2 hrs   | Planned - SUBMIT            |            |             |                | QLD<br>Maintenance<br>8 Hours            |
| VIC    | AusNet     | 29/10/2025 06:00<br>Wednesday | 29/10/2025 17:00<br>Wednesday | South Morang - Sydenham No.2 500 kV<br>Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria  • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).                                    | Day: NA<br>Night: NA         | Planned - SUBMIT            |            |             |                | VIC<br>Maintenance<br>11 Hours           |
| VIC    | AusNet     | 30/10/2025 06:00<br>Thursday  | 30/10/2025 17:00<br>Thursday  | South Morang - Sydenham No.2 500 kV<br>Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria  • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).                                    | Day: NA<br>Night: NA         | Planned - SUBMIT            |            |             |                | VIC<br>Maintenance<br>11 Hours           |
| SA     | ElectraNet | 30/10/2025 07:30<br>Thursday  | 04/11/2025 16:30<br>Tuesday   | Tailem Bend - Tungkillo No.1 275 kV Line    | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 10 hrs<br>Night: 10 hrs | Planned - SUBMIT            |            |             |                | SA<br>Maintenance<br>5.4 Days            |
| QLD    | Powerlink  | 03/11/2025 07:00<br>Monday    | 03/11/2025 17:00<br>Monday    | Strathmore - Ross (8857) 275 kV Line        | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.  | Day: 30 mins<br>Night: NA    | Planned - SUBMIT            |            |             |                | QLD<br>Commissioning<br>10 Hours         |

| Region | NSP        | Start                         | Finish                        | Network Asset                            | Impact  | Recall                       | Status and<br>Market Notice | Unplanned? | DNSP Aware? | Inter-Regional | Impact Region,<br>Reason and<br>Duration |
|--------|------------|-------------------------------|-------------------------------|--|---|------------------------------|-----------------------------|------------|-------------|----------------|--|
| QLD    | Powerlink  | 04/11/2025 07:00<br>Tuesday   | 04/11/2025 17:00<br>Tuesday   | Strathmore - Ross (8857) 275 kV Line     | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.  | Day: 30 mins<br>Night: NA    | Planned - SUBMIT            |            |             |                | QLD<br>Commissioning<br>10 Hours         |
| QLD    | Powerlink  | 05/11/2025 07:00<br>Wednesday | 05/11/2025 17:00<br>Wednesday | Strathmore - Ross (8857) 275 kV Line     | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.  | Day: 30 mins<br>Night: NA    | Planned - SUBMIT            |            |             |                | QLD<br>Commissioning<br>10 Hours         |
| QLD    | Powerlink  | 06/11/2025 07:00<br>Thursday  | 06/11/2025 17:00<br>Thursday  | Strathmore - Ross (8857) 275 kV Line     | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.  | Day: 30 mins<br>Night: NA    | Planned - SUBMIT            |            |             |                | QLD<br>Commissioning<br>10 Hours         |
| QLD    | Powerlink  | 07/11/2025 07:00<br>Friday    | 07/11/2025 17:00<br>Friday    | Strathmore - Ross (8857) 275 kV Line     | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.  | Day: 30 mins<br>Night: NA    | Planned - SUBMIT            |            |             |                | QLD<br>Commissioning<br>10 Hours         |
| QLD    | Powerlink  | 08/11/2025 07:00<br>Saturday  | 08/11/2025 17:00<br>Saturday  | Strathmore - Ross (8857) 275 kV Line     | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.  | Day: 30 mins<br>Night: NA    | Planned - SUBMIT            |            |             |                | QLD<br>Commissioning<br>10 Hours         |
| QLD    | Powerlink  | 09/11/2025 07:00<br>Sunday    | 09/11/2025 17:00<br>Sunday    | Strathmore - Ross (8857) 275 kV Line     | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.  | Day: 30 mins<br>Night: NA    | Planned - SUBMIT            |            |             |                | QLD<br>Commissioning<br>10 Hours         |
| NSW    | Transgrid  | 10/11/2025 06:00<br>Monday    | 15/11/2025 16:00<br>Saturday  | Armidale - Dumaresq (8C) 330 kV Line     | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM  | Day: 6 hrs<br>Night: 6 hrs   | Planned - SUBMIT            |            | ~           | · /            | NSW / QLD<br>Commissioning<br>5.4 Days   |
| SA     | ElectraNet | 11/11/2025 07:30<br>Tuesday   | 16/11/2025 16:30<br>Sunday    | Tailem Bend - Tungkillo No.1 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  Post contingent FCAS will be sourced within SA following Separation event. | Day: 10 hrs<br>Night: 10 hrs | Planned - SUBMIT            |            |             |                | SA<br>Maintenance<br>5.4 Days            |

| Region | NSP       | Start                         | Finish                        | Network Asset  | Impact   | Recall                       | Status and<br>Market Notice |   | DivsP Awarer<br>Generator Aware? | Inter-Regional | Impact Region,<br>Reason and<br>Duration |
|--------|-----------|-------------------------------|-------------------------------|--|--|------------------------------|-----------------------------|---|----------------------------------|----------------|--|
| VIC    | AusNet    | 21/11/2025 06:00<br>Friday    | 21/11/2025 17:00<br>Friday    | Moorabool–Sydenham No.2 500 kV Line                    | < <this been="" has="" outage="" withdrawn!="">&gt; A credible contingency event during this planned outage may require market intervention through issuing of directions</this>   | Day: 24 hrs<br>Night: NA     | Withdraw Requested          |   |                                  |                | VIC<br>Maintenance<br>11 Hours           |
| VIC    | AusNet    | 21/11/2025 06:00<br>Friday    | 22/11/2025 17:00<br>Saturday  | Moorabool–Sydenham No.2 500 kV Line                    | < <new last="" notification="" since="" the="">&gt; A credible contingency event during this planned outage may require market intervention through issuing of directions</new>  | Day: 60 hrs<br>Night: NA     | Planned - RESUBMIT          |   |                                  |                | VIC<br>Maintenance<br>1.5 Days           |
| QLD    | Powerlink | 24/11/2025 08:00<br>Monday    | 28/11/2025 17:00<br>Friday    | Nebo - Strathmore (822) 275 kV Line                    | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.   | Day: 48 hrs<br>Night: 48 hrs | Planned - SUBMIT            | , | / /                              |                | QLD<br>Maintenance<br>4.4 Days           |
| VIC    | AusNet    | 11/12/2025 06:00<br>Thursday  | 11/12/2025 15:30<br>Thursday  | South Morang - Sydenham No.2 500 kV<br>Line            | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria  • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 2 hrs<br>Night: NA      | Planned - SUBMIT            |   |                                  |                | VIC<br>Maintenance<br>9.5 Hours          |
| VIC    | AusNet    | 12/12/2025 06:00<br>Friday    | 12/12/2025 15:30<br>Friday    | South Morang - Sydenham No.1 500 kV<br>Line            | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).  | Day: 2 hrs<br>Night: NA      | Planned - SUBMIT            |   |                                  |                | VIC<br>Maintenance<br>9.5 Hours          |
| VIC    | AusNet    | 17/12/2025 06:00<br>Wednesday | 17/12/2025 14:00<br>Wednesday | Kiamal SF-Red Cliffs 220 kV LINE                       | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.  | Day: 2 hrs<br>Night: NA      | Planned - SUBMIT            |   |                                  |                | VIC<br>Maintenance<br>8 Hours            |
| VIC    | AusNet    | 31/12/2025 06:00<br>Wednesday | 31/12/2025 17:00<br>Wednesday | Kiamal SF - MurraWarra 220 kV Line                     | A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.  | Day: 2 hrs<br>Night: NA      | Planned - SUBMIT            |   |                                  |                | VIC<br>Maintenance<br>11 Hours           |
| VIC    | AusNet    | 31/12/2025 06:30<br>Wednesday | 31/12/2025 15:00<br>Wednesday | Hazelwood - Loy Yang Power Station No.1<br>500 kV Line | A credible contingency event during this planned outage could cause:  • A large reduction in generation in Victoria  • Load shedding in Victoria   | Day: 1 hr<br>Night: NA       | Planned - SUBMIT            |   |                                  |                | VIC<br>Maintenance<br>8.5 Hours          |

| Region | NSP         | Start                         | Finish                        | Network Asset  | Impact  | Recall                       | Status and<br>Market Notice | Unplanned?<br>DNSP Aware? | Generator Aware? | Inter-Regional Reason Dura | n and          |
|--------|-------------|-------------------------------|-------------------------------|--|---|------------------------------|-----------------------------|---------------------------|------------------|----------------------------|----------------|
| QLD    | Powerlink   | 12/01/2026 07:00<br>Monday    | 16/01/2026 17:00<br>Friday    | Strathmore - Ross (8857) 275 kV Line                   | < <new last="" notification="" since="" the="">&gt; This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.</new> | Day: 24 hrs<br>Night: 18 hrs | Planned - SUBMIT            |                           |                  | QL<br>Commis<br>4.4 E      | ssioning       |
| VIC    | AusNet      | 21/01/2026 06:00<br>Wednesday | 21/01/2026 18:00<br>Wednesday | Moorabool–Sydenham No.1 500 kV Line                    | A credible contingency event during this planned outage<br>may require market intervention through issuing of<br>directions   | Day: 2 hrs<br>Night: NA      | Planned - SUBMIT            |                           |                  | VI<br>Mainte<br>12 Ho      | enance         |
| VIC    | AusNet      | 22/01/2026 06:00<br>Thursday  | 22/01/2026 18:00<br>Thursday  | Moorabool–Sydenham No.1 500 kV Line                    | A credible contingency event during this planned outage may require market intervention through issuing of directions   | Day: 2 hrs<br>Night: NA      | Planned - SUBMIT            |                           |                  | VI<br>Mainte<br>12 Ho      | enance<br>ours |
| TAS    | TasNetworks | 28/01/2026 07:00<br>Wednesday | 28/01/2026 16:00<br>Wednesday | Sheffield - Farrell No.2 220 kV Line                   | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.  | Day: 24 hrs<br>Night: 24 hrs | Planned - SUBMIT            |                           | <b>✓</b>         | TA<br>Commis<br>9 Ho       | sioning        |
| VIC    | AusNet      | 11/02/2026 06:00<br>Wednesday | 11/02/2026 18:00<br>Wednesday | Moorabool–Sydenham No.1 500 kV Line                    | A credible contingency event during this planned outage may require market intervention through issuing of directions   | Day: 2 hrs<br>Night: NA      | Planned - SUBMIT            |                           |                  | VI<br>Mainte<br>12 Ho      | enance         |
| VIC    | AusNet      | 20/02/2026 06:00<br>Friday    | 20/02/2026 18:00<br>Friday    | Moorabool–Sydenham No.2 500 kV Line                    | A credible contingency event during this planned outage may require market intervention through issuing of directions   | Day: 4 hrs<br>Night: NA      | Planned - SUBMIT            |                           |                  | VI<br>Mainte<br>12 Ho      | enance         |
| VIC    | AusNet      | 21/02/2026 06:00<br>Saturday  | 21/02/2026 18:00<br>Saturday  | Moorabool–Sydenham No.2 500 kV Line                    | A credible contingency event during this planned outage may require market intervention through issuing of directions   | Day: 4 hrs<br>Night: NA      | Planned - SUBMIT            |                           |                  | VI<br>Mainte<br>12 Ho      | enance         |
| VIC    | AusNet      | 22/02/2026 06:00<br>Sunday    | 22/02/2026 18:00<br>Sunday    | Moorabool–Sydenham No.2 500 kV Line                    | A credible contingency event during this planned outage may require market intervention through issuing of directions   | Day: 4 hrs<br>Night: NA      | Planned - SUBMIT            |                           |                  | VI<br>Mainte<br>12 Ho      | enance         |
| VIC    | AusNet      | 23/02/2026 06:00<br>Monday    | 23/02/2026 18:00<br>Monday    | Moorabool–Sydenham No.1 500 kV Line                    | A credible contingency event during this planned outage may require market intervention through issuing of directions   | Day: 4 hrs<br>Night: NA      | Planned - RESUBMIT          |                           |                  | VI<br>Mainte<br>12 Ho      | enance         |
| VIC    | AusNet      | 24/02/2026 06:00<br>Tuesday   | 24/02/2026 18:00<br>Tuesday   | Moorabool–Sydenham No.1 500 kV Line                    | < <new last="" notification="" since="" the="">&gt; A credible contingency event during this planned outage may require market intervention through issuing of directions</new>   | Day: 4 hrs<br>Night: NA      | Planned - RESUBMIT          |                           |                  | VI<br>Mainte<br>12 Ho      | enance<br>ours |
| VIC    | AusNet      | 25/02/2026 06:00<br>Wednesday | 25/02/2026 18:00<br>Wednesday | Moorabool–Sydenham No.1 500 kV Line                    | A credible contingency event during this planned outage may require market intervention through issuing of directions   | Day: 4 hrs<br>Night: NA      | Planned - RESUBMIT          |                           |                  | VI<br>Mainte<br>12 Ho      | enance         |
| VIC    | AusNet      | 05/03/2026 06:00<br>Thursday  | 06/03/2026 15:30<br>Friday    | Hazelwood - Loy Yang Power Station No.3<br>500 kV Line | < <new last="" notification="" since="" the="">&gt; A credible contingency event during this planned outage could cause:  • A large reduction in generation in Victoria • Load shedding in Victoria</new>   | Day: 2 hrs<br>Night: NA      | Planned - SUBMIT            |                           |                  | VI<br>Mainte<br>1.4 C      | enance         |

| Region | NSP       | Start                         | Finish                        | Network Asset                               | Impact   | Recall                       | Status and<br>Market Notice | Unplanned? | DNSP Aware:<br>Generator Aware? | Inter-Regional | Impact Region,<br>Reason and<br>Duration |
|--------|-----------|-------------------------------|-------------------------------|---|--|------------------------------|-----------------------------|------------|---------------------------------|----------------|--|
| NSW    | Transgrid | 07/03/2026 05:00<br>Saturday  | 08/03/2026 17:00<br>Sunday    | Lower Tumut - Wagga (051) 330 kV Line       | This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer  • Between Victoria and New South Wales.  • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.  | Day: 18 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                                 |                | NSW/ VIC<br>Commissioning<br>1.5 Days    |
| VIC    | AusNet    | 11/03/2026 06:00<br>Wednesday | 13/03/2026 16:00<br>Friday    | Heywood - South East No.2 275 kV Line       | < <new last="" notification="" since="" the="">&gt; A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 1 hr<br>Night: NA       | Planned - SUBMIT            |            |                                 |                | VIC / SA<br>Maintenance<br>2.4 Days      |
| NSW    | Transgrid | 17/03/2026 06:00<br>Tuesday   | 28/03/2026 16:00<br>Saturday  | Armidale - Dumaresq (8C) 330 kV Line        | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM   | Day: 6 hrs<br>Night: 6 hrs   | Planned - SUBMIT            |            | <b>✓</b>                        | √              | NSW / QLD<br>Commissioning<br>11.4 Days  |
| VIC    | AusNet    | 17/03/2026 06:00<br>Tuesday   | 19/03/2026 16:00<br>Thursday  | Heywood - South East No.1 275 kV Line       | < <new last="" notification="" since="" the="">&gt; A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</new> | Day: 1 hr<br>Night: NA       | Planned - SUBMIT            |            |                                 |                | VIC / SA<br>Maintenance<br>2.4 Days      |
| VIC    | AusNet    | 27/03/2026 06:00<br>Friday    | 01/04/2026 17:00<br>Wednesday | South Morang - Sydenham No.1 500 kV<br>Line | < <new last="" notification="" since="" the="">&gt; This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:  • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).</new>                                  | Day: 120 hrs<br>Night: NA    | Planned - RESUBMIT          |            |                                 |                | VIC<br>Maintenance<br>5.5 Days           |

| Region | NSP       | Start                         | Finish                        | Network Asset                               | Impact  | Recall                       | Status and<br>Market Notice | Unplanned? |   | Inter-Regional | Impact Region,<br>Reason and<br>Duration |
|--------|-----------|-------------------------------|-------------------------------|---|---|------------------------------|-----------------------------|------------|---|----------------|--|
| NSW    | Transgrid | 30/03/2026 06:00<br>Monday    | 04/04/2026 16:00<br>Saturday  | Armidale - Dumaresq (8C) 330 kV Line        | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM  | Day: 6 hrs<br>Night: 6 hrs   | Planned - SUBMIT            |            | ✓ | <b>✓</b>       | NSW / QLD<br>Commissioning<br>5.4 Days   |
| VIC    | AusNet    | 01/04/2026 06:00<br>Wednesday | 02/04/2026 17:00<br>Thursday  | Moorabool–Sydenham No.1 500 kV Line         | < <new last="" notification="" since="" the="">&gt; A credible contingency event during this planned outage may require market intervention through issuing of directions</new>   | Day: 120 hrs<br>Night: NA    | Planned - SUBMIT            |            |   |                | VIC<br>Maintenance<br>1.5 Days           |
| VIC    | AusNet    | 05/04/2026 07:00<br>Sunday    | 06/04/2026 18:00<br>Monday    | Moorabool–Sydenham No.2 500 kV Line         | < <new last="" notification="" since="" the="">&gt; A credible contingency event during this planned outage may require market intervention through issuing of directions</new>   | Day: 120 hrs<br>Night: NA    | Planned - SUBMIT            |            |   |                | VIC<br>Maintenance<br>1.5 Days           |
| NSW    | Transgrid | 14/04/2026 07:00<br>Tuesday   | 25/04/2026 17:00<br>Saturday  | Armidale - Sapphire WF (8E) 330 kV Line     | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM  | Day: 12 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |   |                | NSW / QLD<br>Commissioning<br>11.4 Days  |
| VIC    | AusNet    | 19/04/2026 07:00<br>Sunday    | 24/04/2026 18:00<br>Friday    | South Morang - Sydenham No.2 500 kV<br>Line | < <new last="" notification="" since="" the="">&gt; This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: <ul> <li>Cause a large reduction in generation in Victoria</li> <li>Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).</li> </ul></new> | Day: 120 hrs<br>Night: NA    | Planned - SUBMIT            |            |   |                | VIC<br>Maintenance<br>5.5 Days           |
| VIC    | AusNet    | 21/04/2026 07:00<br>Tuesday   | 22/04/2026 17:00<br>Wednesday | Ararat - Crowlands 220kV Line               | <new last="" notification="" since="" the="">&gt; A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions.</new>   | Day: 2 hrs<br>Night: NA      | Planned - SUBMIT            |            |   |                | VIC<br>Maintenance<br>1.4 Days           |
| VIC    | AusNet    | 23/04/2026 07:00<br>Thursday  | 24/04/2026 17:00<br>Friday    | Crowland - Bulgana 220 kV Line              | < <new last="" notification="" since="" the="">&gt; A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.</new>   | Day: 2 hrs<br>Night: NA      | Planned - SUBMIT            |            |   |                | VIC<br>Maintenance<br>1.4 Days           |
| NSW    | Transgrid | 27/04/2026 07:00<br>Monday    | 02/05/2026 17:00<br>Saturday  | Armidale - Sapphire WF (8E) 330 kV Line     | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM  | Day: 12 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |   |                | NSW / QLD<br>Commissioning<br>5.4 Days   |
| VIC    | AusNet    | 05/05/2026 07:00<br>Tuesday   | 06/05/2026 17:00<br>Wednesday | Ararat - Crowlands 220kV Line               | < <new last="" notification="" since="" the="">&gt; A credible contingency event during this planned outage may require: <ul> <li>Load shedding in the Victorian outer grid</li> <li>Market intervention through issuing of directions.</li> </ul></new>  | Day: 2 hrs<br>Night: NA      | Planned - SUBMIT            |            |   |                | VIC<br>Maintenance<br>1.4 Days           |

| Region | NSP        | Start                         | Finish                        | Network Asset                             | Impact   | Recall                       | Status and<br>Market Notice | Unplanned?<br>DNSP Aware? | Generator Aware? | Impact Region, Reason and Duration      |
|--------|------------|-------------------------------|-------------------------------|---|--|------------------------------|-----------------------------|---------------------------|------------------|---|
| VIC    | AusNet     | 06/05/2026 07:30<br>Wednesday | 06/05/2026 16:30<br>Wednesday | Hazelwood - Cranbourne 500 kV Line        | <new last="" notification="" since="" the="">&gt; This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: Cause a large reduction in generation in Victoria Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 2 hrs<br>Night: NA      | Planned - SUBMIT            |                           |                  | VIC<br>Maintenance<br>9 Hours           |
| NSW    | Transgrid  | 12/05/2026 07:00<br>Tuesday   | 23/05/2026 17:00<br>Saturday  | Armidale - Sapphire WF (8E) 330 kV Line   | A credible contingency event during this planned outage could cause:  Synchronous separation of the Queensland region from the rest of the NEM   | Day: 12 hrs<br>Night: 12 hrs | Planned - SUBMIT            |                           |                  | NSW / QLD<br>Commissioning<br>11.4 Days |
| NSW    | Transgrid  | 25/05/2026 07:00<br>Monday    | 30/05/2026 17:00<br>Saturday  | Armidale - Sapphire WF (8E) 330 kV Line   | A credible contingency event during this planned outage could cause:  Synchronous separation of the Queensland region from the rest of the NEM   | Day: 12 hrs<br>Night: 12 hrs | Planned - SUBMIT            |                           |                  | NSW / QLD<br>Commissioning<br>5.4 Days  |
| SA     | ElectraNet | 29/06/2026 07:30<br>Monday    | 05/07/2026 17:30<br>Sunday    | Tailem Bend - South East No.1 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  Post contingent FCAS will be sourced within SA following Separation event.                    | Day: 6 hrs<br>Night: 12 hrs  | Planned - SUBMIT            |                           |                  | SA<br>Maintenance<br>6.4 Days           |
| SA     | ElectraNet | 06/07/2026 07:30<br>Monday    | 12/07/2026 17:30<br>Sunday    | Tailem Bend - South East No.2 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  Post contingent FCAS will be sourced within SA following Separation event.                    | Day: 6 hrs<br>Night: 12 hrs  | Planned - SUBMIT            |                           |                  | SA<br>Maintenance<br>6.4 Days           |

| Region | NSP        | Start                      | Finish                     | Network Asset                            | Impact  | Recall                      | Status and<br>Market Notice | Unplanned? | Generator Aware? | Inter-Regional | Impact Region,<br>Reason and<br>Duration |
|--------|------------|----------------------------|----------------------------|--|---|-----------------------------|-----------------------------|------------|------------------|----------------|--|
| SA     | ElectraNet | 13/07/2026 07:30<br>Monday | 19/07/2026 19:30<br>Sunday | Heywood - South East No.1 275 kV Line    | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  | *              | VIC / SA<br>Maintenance<br>6.5 Days      |
| SA     | ElectraNet | 20/07/2026 07:30<br>Monday | 26/07/2026 17:30<br>Sunday | Heywood - South East No.2 275 kV Line    | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  | <b>✓</b>       | VIC / SA<br>Maintenance<br>6.4 Days      |
| SA     | ElectraNet | 27/07/2026 07:30<br>Monday | 02/08/2026 17:30<br>Sunday | Tailem Bend - Tungkillo No.1 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  |                | SA<br>Maintenance<br>6.4 Days            |
| SA     | ElectraNet | 03/08/2026 07:30<br>Monday | 09/08/2026 17:30<br>Sunday | Tailem Bend - Tungkillo No.2 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  Post contingent FCAS will be sourced within SA following Separation event.     | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  |                | SA<br>Maintenance<br>6.4 Days            |

| Region | NSP        | Start                      | Finish                     | Network Asset                             | Impact  | Recall                      | Status and<br>Market Notice | Unplanned? | Generator Aware? | Inter-Regional<br> | mpact Region,<br>Reason and<br>Duration |
|--------|------------|----------------------------|----------------------------|---|---|-----------------------------|-----------------------------|------------|------------------|--------------------|---|
| SA     | ElectraNet | 28/06/2027 07:30<br>Monday | 04/07/2027 17:30<br>Sunday | Tailem Bend - South East No.1 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  |                    | SA<br>Maintenance<br>6.4 Days           |
| SA     | ElectraNet | 05/07/2027 07:30<br>Monday | 11/07/2027 17:30<br>Sunday | Tailem Bend - South East No.2 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  Post contingent FCAS will be sourced within SA following Separation event.     | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  |                    | SA<br>Maintenance<br>6.4 Days           |
| SA     | ElectraNet | 12/07/2027 07:30<br>Monday | 18/07/2027 19:30<br>Sunday | Heywood - South East No.1 275 kV Line     | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  | ✓                  | VIC / SA<br>Maintenance<br>6.5 Days     |
| SA     | ElectraNet | 19/07/2027 07:30<br>Monday | 25/07/2027 17:30<br>Sunday | Heywood - South East No.2 275 kV Line     | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  | <b>✓</b>           | VIC / SA<br>Maintenance<br>6.4 Days     |

| Region | NSP        | Start                      | Finish                     | Network Asset                             | Impact  | Recall                      | Status and<br>Market Notice | Unplanned? | Generator Aware? | bn a | mpact Region,<br>Reason and<br>Duration |
|--------|------------|----------------------------|----------------------------|---|---|-----------------------------|-----------------------------|------------|------------------|------|---|
| SA     | ElectraNet | 26/07/2027 07:30<br>Monday | 01/08/2027 17:30<br>Sunday | Tailem Bend - Tungkillo No.1 275 kV Line  | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  |      | SA<br>Maintenance<br>6.4 Days           |
| SA     | ElectraNet | 02/08/2027 07:30<br>Monday | 08/08/2027 17:30<br>Sunday | Tailem Bend - Tungkillo No.2 275 kV Line  | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  |      | SA<br>Maintenance<br>6.4 Days           |
| SA     | ElectraNet | 26/06/2028 07:30<br>Monday | 02/07/2028 17:30<br>Sunday | Tailem Bend - South East No.1 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  |      | SA<br>Maintenance<br>6.4 Days           |
| SA     | ElectraNet | 03/07/2028 07:30<br>Monday | 09/07/2028 17:30<br>Sunday | Tailem Bend - South East No.2 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  |      | SA<br>Maintenance<br>6.4 Days           |

| Region | NSP        | Start                      | Finish                     | Network Asset                            | Impact  | Recall                      | Status and<br>Market Notice | Unplanned? | Generator Aware? | Inter-Regional | Impact Region,<br>Reason and<br>Duration |
|--------|------------|----------------------------|----------------------------|--|---|-----------------------------|-----------------------------|------------|------------------|----------------|--|
| SA     | ElectraNet | 10/07/2028 07:30<br>Monday | 16/07/2028 19:30<br>Sunday | Heywood - South East No.1 275 kV Line    | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  | *              | VIC / SA<br>Maintenance<br>6.5 Days      |
| SA     | ElectraNet | 17/07/2028 07:30<br>Monday | 23/07/2028 17:30<br>Sunday | Heywood - South East No.2 275 kV Line    | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  | <b>✓</b>       | VIC / SA<br>Maintenance<br>6.4 Days      |
| SA     | ElectraNet | 24/07/2028 07:30<br>Monday | 30/07/2028 17:30<br>Sunday | Tailem Bend - Tungkillo No.1 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  |                | SA<br>Maintenance<br>6.4 Days            |
| SA     | ElectraNet | 31/07/2028 07:30<br>Monday | 06/08/2028 17:30<br>Sunday | Tailem Bend - Tungkillo No.2 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  Post contingent FCAS will be sourced within SA following Separation event.     | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  |                | SA<br>Maintenance<br>6.4 Days            |

| Region | NSP        | Start                      | Finish                     | Network Asset                             | Impact  | Recall                      | Status and<br>Market Notice | Unplanned?<br>DNSP Aware? | Generator Aware? | Inter-Regional | Impact Region,<br>Reason and<br>Duration |
|--------|------------|----------------------------|----------------------------|---|---|-----------------------------|-----------------------------|---------------------------|------------------|----------------|--|
| SA     | ElectraNet | 02/07/2029 07:30<br>Monday | 08/07/2029 17:30<br>Sunday | Tailem Bend - South East No.1 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |                           |                  |                | SA<br>Maintenance<br>6.4 Days            |
| SA     | ElectraNet | 09/07/2029 07:30<br>Monday | 15/07/2029 17:30<br>Sunday | Tailem Bend - South East No.2 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  Post contingent FCAS will be sourced within SA following Separation event.     | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |                           |                  |                | SA<br>Maintenance<br>6.4 Days            |
| SA     | ElectraNet | 16/07/2029 07:30<br>Monday | 22/07/2029 19:30<br>Sunday | Heywood - South East No.1 275 kV Line     | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |                           |                  | <b>✓</b>       | VIC / SA<br>Maintenance<br>6.5 Days      |
| SA     | ElectraNet | 23/07/2029 07:30<br>Monday | 29/07/2029 17:30<br>Sunday | Heywood - South East No.2 275 kV Line     | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |                           |                  | <b>*</b>       | VIC / SA<br>Maintenance<br>6.4 Days      |

| Region | NSP        | Start                      | Finish                     | Network Asset                             | Impact  | Recall                      | Status and<br>Market Notice | Unplanned? | Generator Aware? | Inter-Regional | Impact Region,<br>Reason and<br>Duration |
|--------|------------|----------------------------|----------------------------|---|---|-----------------------------|-----------------------------|------------|------------------|----------------|--|
| SA     | ElectraNet | 30/07/2029 07:30<br>Monday | 05/08/2029 17:30<br>Sunday | Tailem Bend - Tungkillo No.1 275 kV Line  | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  |                | SA<br>Maintenance<br>6.4 Days            |
| SA     | ElectraNet | 06/08/2029 07:30<br>Monday | 12/08/2029 17:30<br>Sunday | Tailem Bend - Tungkillo No.2 275 kV Line  | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  |                | SA<br>Maintenance<br>6.4 Days            |
| SA     | ElectraNet | 01/07/2030 07:30<br>Monday | 07/07/2030 17:30<br>Sunday | Tailem Bend - South East No.1 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  |                | SA<br>Maintenance<br>6.4 Days            |
| SA     | ElectraNet | 08/07/2030 07:30<br>Monday | 14/07/2030 17:30<br>Sunday | Tailem Bend - South East No.2 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  |                | SA<br>Maintenance<br>6.4 Days            |

| Region | NSP        | Start                      | Finish                     | Network Asset                            | Impact  | Recall                      | Status and<br>Market Notice | Unplanned? | Generator Aware? | Inter-Regional | Impact Region,<br>Reason and<br>Duration |
|--------|------------|----------------------------|----------------------------|--|---|-----------------------------|-----------------------------|------------|------------------|----------------|--|
| SA     | ElectraNet | 15/07/2030 07:30<br>Monday | 21/07/2030 19:30<br>Sunday | Heywood - South East No.1 275 kV Line    | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  | *              | VIC / SA<br>Maintenance<br>6.5 Days      |
| SA     | ElectraNet | 22/07/2030 07:30<br>Monday | 28/07/2030 17:30<br>Sunday | Heywood - South East No.2 275 kV Line    | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  | <b>✓</b>       | VIC / SA<br>Maintenance<br>6.4 Days      |
| SA     | ElectraNet | 29/07/2030 07:30<br>Monday | 04/08/2030 17:30<br>Sunday | Tailem Bend - Tungkillo No.1 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  |                | SA<br>Maintenance<br>6.4 Days            |
| SA     | ElectraNet | 05/08/2030 07:30<br>Monday | 11/08/2030 17:30<br>Sunday | Tailem Bend - Tungkillo No.2 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  Post contingent FCAS will be sourced within SA following Separation event.     | Day: 6 hrs<br>Night: 12 hrs | Planned - SUBMIT            |            |                  |                | SA<br>Maintenance<br>6.4 Days            |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and<br>Market Notice | Unplanned?  DNSP Aware? Generator Aware? Inter-Regional Onumber of the control of |
|--------|-----|-------|--------|---------------|--------|--------|-----------------------------|--|
|--------|-----|-------|--------|---------------|--------|--------|-----------------------------|--|

## The following fields of data are submitted by NSPs to AEMO.

- ✓ **Unplanned** Outage is forced outage, trip or submitted with short notice.
- ✓ DNSP(s) Aware The TNSP that submitted the outage confirms they have notified DNSP(s) that are impacted by this outage and made aware of the risks of next contingency.
- ✓ Generator(s) Aware The TNSP that submitted the outage confirms they have notified generator(s) that are directly impacted by this outage and made aware of potential risks of next credible contingency.
- ✓ Inter-Regional The TNSP that submitted the outage confirms they have notified other TNSP(s) that may be impacted by this outage, often in the neighbouring region.

## Disclaimer

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice, and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies. AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- \* make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- \* are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.