

Upcoming high-impact outages in the NEM (information as of 11/02/2019 1352 hrs):

Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	12/02/2019 03:00	12/02/2019 15:00	Horsham - Redcliffs 220 kV Line	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. 	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Project work
VIC	AusNet	13/02/2019 03:00	13/02/2019 15:00	Horsham - Redcliffs 220 kV Line	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. 	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Project work
VIC	AusNet	15/02/2019 03:00	15/02/2019 15:00	Horsham - Redcliffs 220 kV Line	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. 	Day: 2.5 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	16/02/2019 03:00	16/02/2019 15:00						
<u>VIC</u>	AusNet	18/02/2019 04:00	18/02/2019 16:00	Crowland - Horsham 220 kV Line	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. 	Day: 4 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	19/02/2019 06:00	19/02/2019 16:00	Crowland - Horsham 220 kV Line	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. 	Day: 4 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	21/02/2019 03:00	21/02/2019 15:00	Horsham - Redcliffs 220 kV Line	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. 	Day: 2.5 hrs Night: Not applicable	Not required	Not required	Project work
<u>VIC</u>	AusNet	22/02/2019 03:00	22/02/2019 15:00						

Upcoming high-impact outages in the NEM (information as of 11/02/2019 1352 hrs):

Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	05/03/2019 03:00	05/03/2019 15:00	Horsham - Redcliffs 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2.5 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	06/03/2019 03:00	06/03/2019 15:00						
VIC	AusNet	09/03/2019 03:00	09/03/2019 15:00	Horsham - Redcliffs 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2.5 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	10/03/2019 03:00	10/03/2019 15:00						
VIC	AusNet	12/03/2019 03:00	12/03/2019 15:00	Horsham - Redcliffs 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2.5 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	13/03/2019 03:00	13/03/2019 15:00						
NSW	Transgrid	25/03/2019 06:00	25/03/2019 15:00	Armidale - Tamworth (85) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 1 hrs Night: No recall	Not required	Being assessed	Maintenance
TAS	TasNetworks	05/04/2019 06:00	05/04/2019 12:00	Sheffield - Farrell No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 1.5 hrs Night: Not applicable	Not required	Being assessed	Maintenance

Disclaimer

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice, and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies.

AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.