

**Upcoming high-impact outages in the NEM (information as of 24/06/2019 1100 hrs):**

Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
QLD	Powerlink	29/05/2019 17:01	25/06/2019 17:00	Nebo - Strathmore (822) 275 kV Line	This is a high impact outage because the recall time is greater than <b>30 minutes</b> . A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: No recall Night: No recall	Not required	Being assessed	Maintenance
VIC	AusNet	24/06/2019 06:00	24/06/2019 16:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	24/06/2019 07:00	24/06/2019 17:30	Moorabool - Mortlake 500 kV Line	<b>This outage has been WITHDRAWN.</b> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> <li>• Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>• Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	Day: 2 hrs Night: Not applicable	To be issued	Invoked	Project work
VIC	AusNet	25/06/2019 06:00	25/06/2019 17:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
QLD	Powerlink	26/06/2019 07:00	05/07/2019 12:01	Stanwell - Broadsound (8831) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may result in shedding Far North QLD load and Lilyvale local load.  Following a credible contingency market intervention through issuing of directions may be required. If market intervention is unsuccessful all of North QLD load would be in a credible risk	Day: No recall Night: No recall	Not required	Invoked	Project work

**Upcoming high-impact outages in the NEM (information as of 24/06/2019 1100 hrs):**

Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
NSW	Transgrid	29/06/2019 08:00	29/06/2019 16:00	Jindera - Wagga (62) 330 kV Line	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer</p> <ul style="list-style-type: none"> <li>• Between Victoria and New South Wales.</li> <li>• Between South Australia and Victoria on Murraylink</li> </ul> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	Day: 4 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	02/07/2019 13:30	02/07/2019 17:30	Wagga - Darlington Point (63) 330 kV Line	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer</p> <ul style="list-style-type: none"> <li>• Between Victoria and New South Wales.</li> <li>• Between South Australia and Victoria on Murraylink</li> </ul> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	Day: 1 hrs Night: No recall	Not required	Being assessed	Maintenance
VIC	AusNet	05/07/2019 06:00	05/07/2019 14:00	Red Cliffs-Wemen 220kV LINE	<p><b>This outage has been WITHDRAWN.</b></p> <p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	05/07/2019 06:00	05/07/2019 15:00	Kerang-Wemen 220kV LINE	<p><b>This outage has been WITHDRAWN.</b></p> <p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work

**Upcoming high-impact outages in the NEM (information as of 24/06/2019 1100 hrs):**

Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
QLD	Powerlink	05/07/2019 12:01	19/07/2019 17:00	Stanwell - Broadsound (8831) 275 kV Line	<p>This is a high impact outage because the recall time is greater than 30 minutes.</p> <p>A credible contingency event during this planned outage may result in shedding Far North QLD load and Lilyvale local load.</p> <p>Following a credible contingency market intervention through issuing of directions may be required. If market intervention is unsuccessful all of North QLD load would be in a credible risk</p>	Day: No recall Night: No recall	Not required	Invoked	Project work
VIC	AusNet	07/07/2019 06:00	07/07/2019 15:30	Kerang-Wemen 220kV LINE	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	08/07/2019 06:00	08/07/2019 15:30						
VIC	AusNet	09/07/2019 07:00	09/07/2019 17:30	Moorabool - Tarrone 500 kV Line	<p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> <li>• Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>• Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	Day: 2 hrs Night: Not applicable	Issued on 13/06/2019	Invoked	Project work

**Upcoming high-impact outages in the NEM (information as of 24/06/2019 1100 hrs):**

Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	10/07/2019 06:00	10/07/2019 15:30	Kerang-Wemen 220kV LINE	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	10/07/2019 07:00	10/07/2019 17:30	Moorabool - Tarrone 500 kV Line	<p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> <li>• Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>• Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	Day: 2 hrs Night: Not applicable	Issued on 13/06/2019	Invoked	Project work
VIC	AusNet	11/07/2019 06:00	11/07/2019 17:00	Kerang-Wemen 220kV LINE	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	11/07/2019 07:00	11/07/2019 17:30	Moorabool - Tarrone 500 kV Line	<p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> <li>• Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>• Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	Day: 2 hrs Night: Not applicable	Issued on 13/06/2019	Invoked	Project work

**Upcoming high-impact outages in the NEM (information as of 24/06/2019 1100 hrs):**

Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	12/07/2019 07:00	12/07/2019 17:30	Moorabool - Tarrone 500 kV Line	<p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> <li>• Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>• Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	<p>Day: 2 hrs Night: Not applicable</p>	<p>Issued on 13/06/2019</p>	<p>Invoked</p>	<p>Project work</p>
<u>VIC</u>	AusNet	13/07/2019 06:00	13/07/2019 17:30	Kerang-Wemen 220kV LINE	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	<p>Day: 2 hrs Night: Not applicable</p>	<p>Not required</p>	<p>Being assessed</p>	<p>Project work</p>
VIC	AusNet	13/07/2019 07:00	13/07/2019 17:30	Moorabool - Tarrone 500 kV Line	<p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> <li>• Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>• Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	<p>Day: 2 hrs Night: Not applicable</p>	<p>Issued on 13/06/2019</p>	<p>Invoked</p>	<p>Project work</p>
VIC	AusNet	14/07/2019 06:00	14/07/2019 17:30	Kerang-Wemen 220kV LINE	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	<p>Day: 2 hrs Night: Not applicable</p>	<p>Not required</p>	<p>Being assessed</p>	<p>Project work</p>

**Upcoming high-impact outages in the NEM (information as of 24/06/2019 1100 hrs):**

Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	15/07/2019 07:00	15/07/2019 17:00	MuraWara-Red Cliffs 220kV LINE	<b>This outage has been WITHDRAWN.</b> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	15/07/2019 07:00	15/07/2019 17:30	Moorabool - Tarrone 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> <li>• Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>• Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	Day: 2 hrs Night: Not applicable	Issued on 13/06/2019	Invoked	Project work
VIC	AusNet	16/07/2019 06:00	16/07/2019 15:00	Kerang-Wemen 220kV LINE	<b>This outage has been WITHDRAWN.</b> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	16/07/2019 06:00	16/07/2019 17:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	Day: 2 hrs Night: Not applicable	Not required	Invoked	Project work
VIC	AusNet	17/07/2019 06:00	17/07/2019 15:30	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	Day: 2 hrs Night: Not applicable	Not required	Invoked	Project work

**Upcoming high-impact outages in the NEM (information as of 24/06/2019 1100 hrs):**

Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	18/07/2019 07:00	18/07/2019 17:00	MuraWara-Red Cliffs 220kV LINE	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	<p>Day: 2 hrs</p> <p>Night: Not applicable</p>	Not required	Being assessed	Project work
VIC	AusNet	19/07/2019 06:00	19/07/2019 15:00	Kerang-Wemen 220kV LINE	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	<p>Day: 2 hrs</p> <p>Night: Not applicable</p>	Not required	Being assessed	Project work
VIC	AusNet	20/07/2019 06:00	20/07/2019 15:00	Kerang-Wemen 220kV LINE	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	<p>Day: 2 hrs</p> <p>Night: Not applicable</p>	Not required	Being assessed	Project work
VIC	AusNet	22/07/2019 06:00	22/07/2019 15:00	Kerang-Wemen 220kV LINE	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	<p>Day: 2 hrs</p> <p>Night: Not applicable</p>	Not required	Being assessed	Project work
VIC	AusNet	23/07/2019 06:00	23/07/2019 15:00						
VIC	AusNet	24/07/2019 07:00	24/07/2019 17:00	Moorabool - Tarrone 500 kV Line	<p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> <li>• Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>• Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	<p>Day: 2 hrs</p> <p>Night: Not applicable</p>	To be issued	Being assessed	Project work

**Upcoming high-impact outages in the NEM (information as of 24/06/2019 1100 hrs):**

Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	25/07/2019 07:00	25/07/2019 17:00	Moorabool - Tarrone 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> <li>Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	Day: 2 hrs Night: Not applicable	To be issued	Being assessed	Project work
VIC	AusNet	26/07/2019 07:00	26/07/2019 17:00						
VIC	AusNet	27/07/2019 07:00	27/07/2019 17:00	Moorabool - Tarrone 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> <li>Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	Day: 2 hrs Night: Not applicable	To be issued	Being assessed	Project work
VIC	AusNet	28/07/2019 07:00	28/07/2019 17:00	Moorabool - Tarrone 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> <li>Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	Day: 2 hrs Night: Not applicable	To be issued	Being assessed	Project work
VIC	AusNet	29/07/2019 07:00	29/07/2019 17:00						
VIC	AusNet	30/07/2019 07:00	30/07/2019 17:00						

**Upcoming high-impact outages in the NEM (information as of 24/06/2019 1100 hrs):**

Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	31/07/2019 07:00	31/07/2019 17:00	Moorabool - Tarrone 500 kV Line	<p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> <li>• Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>• Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	Day: 2 hrs Night: Not applicable	To be issued	Being assessed	Project work
VIC	AusNet	02/08/2019 06:00	02/08/2019 15:00	Kerang-Wemen 220kV LINE	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	03/08/2019 06:00	03/08/2019 15:00	Kerang-Wemen 220kV LINE	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	04/08/2019 06:00	04/08/2019 14:00	Kerang-Wemen 220kV LINE	<p><b>This outage has been WITHDRAWN.</b></p> <p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	05/08/2019 06:00	05/08/2019 14:00	Kerang-Wemen 220kV LINE	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work

**Upcoming high-impact outages in the NEM (information as of 24/06/2019 1100 hrs):**

Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	05/08/2019 07:00	05/08/2019 17:00	Moorabool - Mortlake 500 kV Line	<p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> <li>• Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>• Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	<p>Day: 2 hrs</p> <p>Night: Not applicable</p>	To be issued	Being assessed	Project work
VIC	AusNet	06/08/2019 06:00	06/08/2019 14:00	Kerang-Wemen 220kV LINE	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	<p>Day: 2 hrs</p> <p>Night: Not applicable</p>	Not required	Being assessed	Project work
VIC	AusNet	06/08/2019 07:00	06/08/2019 17:00	Moorabool - Mortlake 500 kV Line	<p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> <li>• Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>• Post contingent FCAS will be sourced within SA following Separation</li> </ul>	<p>Day: 2 hrs</p> <p>Night: Not applicable</p>	To be issued	Being assessed	Project work
QLD	Powerlink	06/08/2019 07:00	06/09/2019 17:00	Broadsound - Nebo (834) 275 kV Line	<p>This is a high impact outage because the recall time is greater than 30 minutes.</p> <p>A credible contingency event during this planned outage may require market intervention through issuing of directions.</p>	<p>Day: No recall</p> <p>Night: No recall</p>	Not required	Being assessed	Maintenance

**Upcoming high-impact outages in the NEM (information as of 24/06/2019 1100 hrs):**

Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	07/08/2019 07:00	07/08/2019 17:00	Moorabool - Mortlake 500 kV Line	<p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> <li>• Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>• Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	Day: 2 hrs Night: Not applicable	To be issued	Being assessed	Project work
VIC	AusNet	08/08/2019 06:00	08/08/2019 14:00	Kerang-Wemen 220kV LINE	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	08/08/2019 07:00	08/08/2019 17:00	Moorabool - Mortlake 500 kV Line	<p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> <li>• Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>• Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	Day: 2 hrs Night: Not applicable	To be issued	Being assessed	Project work
VIC	AusNet	09/08/2019 06:00	09/08/2019 14:00	Kerang-Wemen 220kV LINE	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work

**Upcoming high-impact outages in the NEM (information as of 24/06/2019 1100 hrs):**

Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	09/08/2019 07:00	09/08/2019 17:00	Moorabool - Mortlake 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> <li>• Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>• Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	Day: 2 hrs Night: Not applicable	To be issued	Being assessed	Project work
VIC	AusNet	10/08/2019 07:00	10/08/2019 17:00						
VIC	AusNet	11/08/2019 06:00	12/08/2019 14:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	11/08/2019 06:00	11/08/2019 14:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	11/08/2019 07:00	11/08/2019 17:00	Moorabool - Mortlake 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> <li>• Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>• Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	Day: 2 hrs Night: Not applicable	To be issued	Being assessed	Project work

**Upcoming high-impact outages in the NEM (information as of 24/06/2019 1100 hrs):**

Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	12/08/2019 06:00	12/08/2019 14:00	Kerang-Wemen 220kV LINE	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	<p>Day: 2 hrs</p> <p>Night: Not applicable</p>	Not required	Being assessed	Project work
VIC	AusNet	12/08/2019 07:00	12/08/2019 17:00	Moorabool - Mortlake 500 kV Line	<p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> <li>• Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>• Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	<p>Day: 2 hrs</p> <p>Night: Not applicable</p>	To be issued	Being assessed	Project work
VIC	AusNet	14/08/2019 06:00	14/08/2019 14:00	Kerang-Wemen 220kV LINE	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	<p>Day: 2 hrs</p> <p>Night: Not applicable</p>	Not required	Invoked	Project work
VIC	AusNet	14/08/2019 07:00	14/08/2019 17:00	Moorabool - Mortlake 500 kV Line	<p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> <li>• Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>• Post contingent FCAS will be sourced within SA following Separation</li> </ul>	<p>Day: 2 hrs</p> <p>Night: Not applicable</p>	To be issued	Being assessed	Project work

**Upcoming high-impact outages in the NEM (information as of 24/06/2019 1100 hrs):**

Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	15/08/2019 06:00	15/08/2019 14:00	Kerang-Wemen 220kV LINE	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	<p>Day: 2 hrs</p> <p>Night: Not applicable</p>	Not required	Invoked	Project work
VIC	AusNet	28/08/2019 07:00	28/08/2019 17:00	MuraWara-Red Cliffs 220kV LINE	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	<p>Day: 2 hrs</p> <p>Night: Not applicable</p>	Not required	Being assessed	Project work
VIC	AusNet	29/08/2019 07:00	29/08/2019 17:00	Moorabool - Tarrone 500 kV Line	<p><b>This outage has been WITHDRAWN.</b></p> <p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> <li>• Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>• Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	<p>Day: 4 hrs</p> <p>Night: Not applicable</p>	To be issued	Being assessed	Project work
VIC	AusNet	29/08/2019 07:00	29/08/2019 17:00	Murra Warra - Red Cliffs 220 kV Line	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	<p>Day: 2 hrs</p> <p>Night: Not applicable</p>	Not required	Being assessed	Project work

**Upcoming high-impact outages in the NEM (information as of 24/06/2019 1100 hrs):**

Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	03/09/2019 07:00	03/09/2019 17:00	Moorabool - Tarrone 500 kV line	<p><b>This outage has been WITHDRAWN.</b></p> <p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> <li>• Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>• Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	Day: 4 hrs Night: Not applicable	To be issued	Being assessed	Project work
NSW	Transgrid	04/09/2019 07:00	04/09/2019 17:00	Armidale - Tamworth (85 or 86) 330 kV line	<p>A credible contingency event during this planned outage could cause:</p> <ul style="list-style-type: none"> <li>• Synchronous separation of the Queensland region from the rest of the NEM</li> </ul>	Day: 3 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	05/09/2019 07:00	05/09/2019 17:00	Armidale - Tamworth (85 or 86) 330 kV line	<p>A credible contingency event during this planned outage could cause:</p> <ul style="list-style-type: none"> <li>• Synchronous separation of the Queensland region from the rest of the NEM</li> </ul>	Day: 3 hrs Night: No recall	Not required	Being assessed	Maintenance
VIC	AusNet	05/09/2019 07:00	05/09/2019 17:00	Moorabool - Tarrone 500 kV line	<p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> <li>• Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>• Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	Day: 1 hrs Night: Not applicable	To be issued	Being assessed	Project work
VIC	AusNet	06/09/2019 07:00	06/09/2019 17:00						

Upcoming high-impact outages in the NEM (information as of 24/06/2019 1100 hrs):

Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	09/09/2019 07:00	09/09/2019 17:00	Moorabool - Tarrone 500 kV line	<p><b>This outage has been WITHDRAWN.</b>            A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.            During this planned outage:</p> <ul style="list-style-type: none"> <li>• Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>• Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	Day: 2 hrs Night: Not applicable	To be issued	Being assessed	Project work
VIC	AusNet	09/09/2019 07:00	09/09/2019 17:00	Moorabool - Tarrone 500 kV line	<p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.            During this planned outage:</p> <ul style="list-style-type: none"> <li>• Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>• Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	Day: 2 hrs Night: Not applicable	To be issued	Being assessed	Project work
VIC	AusNet	10/09/2019 07:00	10/09/2019 17:00						
VIC	AusNet	11/09/2019 07:00	11/09/2019 17:00						

**Upcoming high-impact outages in the NEM (information as of 24/06/2019 1100 hrs):**

Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	23/09/2019 07:00	23/09/2019 17:00	Heywood - Tarrone 500 kV line	<p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> <li>Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	Day: 4 hrs Night: Not applicable	To be issued	Being assessed	Project work
VIC	AusNet	26/09/2019 07:00	26/09/2019 17:00	Heywood - Tarrone 500 kV line	<p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> <li>Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</li> <li>Post contingent FCAS will be sourced within SA following Separation event.</li> </ul>	Day: 4 hrs Night: Not applicable	To be issued	Being assessed	Project work
VIC	AusNet	28/10/2019 07:00	28/10/2019 17:00	Murra Warra - Red Cliffs 220 kV Line	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>Load shedding in the Victorian outer grid</li> <li>Market intervention through issuing of directions.</li> </ul>	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	29/10/2019 07:00	29/10/2019 17:00	Murra Warra - Red Cliffs 220 kV Line	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> <li>Load shedding in the Victorian outer grid</li> <li>Market intervention through issuing of directions.</li> </ul>	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work

**Upcoming high-impact outages in the NEM (information as of 24/06/2019 1100 hrs):**

Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	30/10/2019 07:00	30/10/2019 17:00	Murra Warra - Red Cliffs 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> <li>• Load shedding in the Victorian outer grid</li> <li>• Market intervention through issuing of directions.</li> </ul>	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	31/10/2019 07:00	31/10/2019 17:00						

**Disclaimer**

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice, and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies. AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.